

From: drainage <drainage@midsussex.gov.uk>
Sent: 03 November 2025 15:05:34 UTC+00:00
To: "Katherine Williams" <Katherine.Williams@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>; "Steve Ashdown" <Steve.Ashdown@midsussex.gov.uk>
Subject: 2025.03.11 Re: DM/25/2472 - Queen Victoria Hospital, Holtye Road, East Grinstead

Dear Katherine,

The Flood Risk and Drainage Team have reviewed the updated information and have the following comments:

The updated calculations indicate a discharge rate exceeding the agreed 3.3 L/s for the 1 in 100-year event plus climate change.

Please provide revised calculations demonstrating a discharge rate no greater than 3.3 L/s.

Upon receipt of this additional information, we will be able to comment further. Receipt of the requested additional information does not mean further information will not be requested.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk