

From: Emily Wade <Emily.Wade@midsussex.gov.uk>
Sent: 16 April 2026 14:56:46 UTC+01:00
To: "Katherine Williams" <Katherine.Williams@midsussex.gov.uk>
Subject: Brook Farm DM/25/1419 and 1563

Hi Katherine

Further comments on the above discharge of conditions application. We have received revised plans, and again further revised plans since my previous comments of 5th March.

Although I do think we are moving forward there are I am afraid still outstanding points:

- The Crittall windows to the west elevation are still retained, and I remain unclear why these are not shown as timber as for all the other windows to the conversion? Apologies if I have missed an argument here.
- With respect to the glazed doors to the façade of the building, these have moved away from the previously shown multi-pane glazing, which is welcomed in terms of retaining the agricultural character of the building, however the doors retain horizontal bars which are not ideal. Can this be revisited? I note the applicant states these are necessary to support the handle plate, however the single glazed door to the east elevation ED.003 does not have these. Ideally, simple glazed doors of this latter type would better reveal the form of the existing openings to the front elevation also.

Thanks,

Emily

Please note that this advice is given at Officer level only and is without prejudice to the formal decision of the District Council.

Submit your planning application online.
<http://www.planningportal.gov.uk>

Emily Wade Ma MSc
Conservation Officer
Planning Services
Tel: +44 (0)1444 477385
emily.wade@midsussex.gov.uk <http://www.midsussex.gov.uk>

The
Electoral
Commission

You now need
photo ID to
vote at a
polling station

No ID? You can apply for free voter ID

Find out more at

electoralcommission.org.uk/voterID

or call 0800 328 0280