

From: hayley cannon <hayleycannon24@hotmail.com>
Sent: 12 August 2025 17:48:22 UTC+01:00
To: "Emily Wade" <Emily.Wade@midsussex.gov.uk>
Cc: "gba Designs" <info@gbadesigns.com>
Subject: Re: DM/25/1481 and 1482 Dorset Arms, High Street, East Grinstead
Attachments: 1000 A Existing Basement Layout - Planning.pdf, 1001 A Existing Ground Floor - Planning.pdf, 1002 A Proposed Basement Layout - Planning.pdf, 1003 B Proposed Ground Floor - Planning.pdf, 1010 Existing Elevations.pdf, 1011 Proposed Elevations.pdf, 1012 Photo Montage to accompany Elevations..pdf

Good evening, Emily,

Please find attached updated and additional drawings for the above site.

Please call or email if you have any queries or require any further information.

I will be on annual leave this Thursday until next Tuesday so please copy Zoe in at GBA on any correspondence. I have copied her in above.

Regards

Hayley

GBA Designs
07708 762511

From: Emily Wade <Emily.Wade@midsussex.gov.uk>
Sent: Monday, July 28, 2025 14:11
To: hayley cannon <hayleycannon24@hotmail.com>
Cc: gba Designs <info@gbadesigns.com>
Subject: Re: DM/25/1481 and 1482 Dorset Arms, High Street, East Grinstead

Dear Hayley

Thank you for your email and attached plan, which addresses the concerns raised in respect of the plan form of the ladies WC.

Thank you also for your agreement to an extension of time- as I am on leave next week and we are awaiting the further revised plans can I suggest Friday 15th August as the revised date? If you could please indicate your agreement by return email I would be grateful.

Kind regards,

Emily Wade

Please note that this advice is given at Officer level only and is without prejudice to the formal decision of the District Council.

Submit your planning application online.
<http://www.planningportal.gov.uk>

Emily Wade Ma MSc
Conservation Officer
Planning Services
Tel: +44 (0)1444 477385
emily.wade@midsussex.gov.uk <http://www.midsussex.gov.uk>



From: hayley cannon <hayleycannon24@hotmail.com>
Sent: 24 July 2025 5:14 PM
To: Emily Wade <emily.wade@midsussex.gov.uk>
Cc: gba Designs <info@gbadesigns.com>
Subject: Fw: DM/25/1481 and 1482 Dorset Arms, High Street, East Grinstead

You don't often get email from hayleycannon24@hotmail.com. [Learn why this is important](#)

Good afternoon Emily,

We have spoken to our clients and the configuration to the ladies has been amended so that no partitions will go through any windows. It means reducing it from three to two cubicles but they are happy with this.

I attach an updated drawing showing this for now but further updated drawings will be issued once we have the information for the drainage routes and vents which will follow.

We can confirm that we agree to a short extension of time.

Regards

Hayley

GBA Designs
07708 762511

From: Office <info@gbadesigns.com>
Sent: Tuesday, July 22, 2025 15:57
To: hayley cannon <hayleycannon24@hotmail.com>
Subject: Fwd: DM/25/1481 and 1482 Dorset Arms, High Street, East Grinstead

Kind regards
Zoe
Follow us on Instagram at gba_designs or X @gbaDesigns

Sent from my iPhone

Begin forwarded message:

From: Emily Wade <Emily.Wade@midsussex.gov.uk>
Date: 22 July 2025 at 15:09:03 BST
To: info@gbadesigns.com
Subject: DM/25/1481 and 1482 Dorset Arms, High Street, East Grinstead

Dear Hayley

Thank you for arranging access to the above site for me today.

Having reviewed the proposal for the new two new WCs and associated works I can confirm that I have no objection in principle in terms of the impact on the special interest of the listed building or the character and appearance of the East Grinstead Conservation Area. However, there are some points which are of potential concern with respect to the detail of the application, which will require further attention and/or amendment:

- there is no commentary either on the proposed plans or within the supporting statements with respect to any new internal or external pipework, soil stacks or vents which may be required. Can you please provide details in this respect, in particular highlighting any impact on the external appearance of the building, or on the internal or external fabric. If new pipework or vents are required to the elevations of the building, appropriate drawings should be provided.
- the proposed new female WC at ground floor involves blocking internally an existing window to the side of the building. Although the

window itself is shown as retained, this will have an adverse impact on the appearance of the building. I would suggest that the window is retained without the infill, but could be fixed shut and obscure glazed. I would recommend that revised plans are submitted to show this amendment to the proposal.

- the female WC also involves partially blocking the rear window to the room concerned, with the partition shown cutting through the window vertically. This is an awkward detail which will again detract from the appearance of the listed building, and requires amendment so that the window is not blocked or bisected by new partitioning.

I note that the existing target date for these applications is 1st August. If necessary, I would be happy to agree a short extension of time to allow for the above further information and revised plans to be provided. Please note that I am on leave from 1st August returning on 11th.

Kind regards,

Emily Wade

Please note that this advice is given at Officer level only and is without prejudice to the formal decision of the District Council.

Submit your planning application online.

<http://www.planningportal.gov.uk>

Emily Wade Ma MSc

Conservation Officer

Planning Services

Tel: +44 (0)1444 477385

emily.wade@midsussex.gov.uk <http://www.midsussex.gov.uk>



The Electoral Commission

You now need photo ID to vote at a polling station

No ID? You can apply for free voter ID

Find out more at

electoralcommission.org.uk/voterID

or call 0800 328 0280

The poster features a purple sticky note with handwritten text on an orange background. The Electoral Commission logo is in the top left. The text on the sticky note reads 'You now need photo ID to vote at a polling station'. To the right, there is text about applying for free voter ID, a website link, and a phone number.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for

information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.