

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 15 April 2025 14:12:38 UTC+00:00
To: "Steven King" <Steven.King@midsussex.gov.uk>
Subject: RE: DM/25/0804

Hi Steve,

The statement regarding the fence is acceptable providing that the fence has a minimum density of 10 kg/m². Please will you confirm with the applicant.

Thanks,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk



"Working together for a better Mid Sussex"

From: Steven King <Steven.King@midsussex.gov.uk>
Sent: 14 April 2025 10:40
To: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Subject: RE: DM/25/0804

Hi Jane

I've received the attached from the applicant in response to your queries.

Regards

Steve

Steven King, BSc (Hons) Dip TP, MRTPI
Team Leader, Major Development
Development Management
01444 477556
www.midsussex.gov.uk

Working together for a better Mid Sussex

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>

Sent: 01 April 2025 16:41

To: Steven King <Steven.King@midsussex.gov.uk>

Subject: DM/25/0804

Discharge of Conditions 6, 7 and 8 in relation to DM/24/0832

Hi Steve,

Condition 8 and 6: Looking at the original application, a 2m high close boarded timber fence is shown to the south facing perimeter of the padel courts. Speaking with Ollie who made comments at the time, this was the proposed acoustic barrier. Please can the applicants confirm that this structure has been provided. This acoustic fence is also mentioned in the NMP submitted.

Condition 7: Please can the applicant provide further details regarding the lighting scheme. What I am trying to establish is whether or not any residents in the immediate locality will be affected by the proposed lighting. I would consider this to be an E2 zone, and would therefore like to know the predicted illuminance (in lux), in the vertical plane at the windows of dwellings in the vicinity so that I can assess any impact from the lights.

Thanks,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk



"Working together for a better Mid Sussex"