

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 08 April 2025 12:59:46 UTC+01:00
To: "Stefan Galyas" <Stefan.Galyas@midsussex.gov.uk>
Subject: DM/25/0593 Little Lower Ease, Cuckfield road, Ansty, Haywards Heath

Dear Stefan,

I have reviewed the Landscaping Plan for this application and find that it is not sufficient.

If trees are within 15m of the development, then a full Arboricultural Impact Assessment is required, which should include a Tree Protection Plan and Arboricultural Method Statement. Further a tree Survey should be included detailing the tree species and categories, in relation to BS5837.

Please could you request this from the agent?

Many thanks.

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex