




Registered Office:
Newington House
237 Southwark Bridge Road
London SE1 6NP

Registered in England and Wales No: 3870728

Company:
UK Power Networks
(Operations) Limited

Our Ref: Deaks Lane, Cuckfield

Planning and Building Control
Mid Sussex District Council
Oaklands
Oaklands Road
Haywards Heath
West Sussex
RH16 1SS



2nd July 2026

Dear Sir/Madam

Electricity Act 1989 – The Overhead Lines (Exemption) (England & Wales) Regulations 2009

This notice is being given to your Council under The Overhead Lines (Exemption) (England & Wales) Regulation 2009.

Under this exemption, your Authority is required to determine, within 6 weeks of receipt of this notice, whether it is considered that the proposal is likely to have a significant adverse effect on the environment.

The works associated with this proposal will commence on site on or after the expiry of the required six weeks notice, unless it becomes necessary to apply to the Secretary of State for Energy Security and Net Zero.


Particulars of proposal:

Location: Deaks Lane, Cuckfield, Haywards Heath, RH17 5JB

Plan No: - S119456

Details of proposal:

As per the attached plan and enclosed detail; To install a new low voltage electricity terminal pole and associated support stay wires in the approximate position shown red or somewhere along the linear route shown yellow on the indicative enclosed plan. To Install a new High voltage electricity H-pole pole shown red to support and upgraded 200kva pole mounted transformer to replace the existing single transformer pole. To upgrade the existing overhead low voltage line route shown pink and yellow from 95 ABC (Ariel bundled conductor) to 120ABC.


Yours faithfully

Jamie White
Asset Management Surveyor
South Eastern Power Networks plc
Mob: 07812262470
Jamie.white@ukpowernetworks.co.uk

Return Address:
UK Power Networks (Operations) Ltd
Operational Property & Consents
Bircholt Road
Park Wood
Maidstone
Kent ME15 9XH

jamie.white@ukpowernetworks.co.uk