



- Entrance - Lighting to be provided with fully diffused luminaries with auto detection.
- Doors to be located centrally within the thickness of the wall.
- Handles to windows are 450-1200mm above floor level with window in living room as handle between 700-1000mm from floor level.
- Radiator controls are mounted 450-1000mm above floor level.
- Kitchen appliances have isolators located 700-1000mm above floor level.
- Switches, sockets and other controls are located 700-1000mm above floor level.
- Power socket and phone point are provided together in living room.
- Fused spur to be provided on hinge side of entrance door.
- Power socket provided for transfer space.
- Kitchen should comply with 3.34 in relation to kitchen detailed design.
- Ceiling within bedroom to be strong enough to allow for the fitting of overhead light ( min 200kg loading).
- All walls, doors, boxings and ceilings within the bathroom should be able to take the required loading.
- All sanitary facilities should be specified with regard to section 3.36.
- All services and controls set out and specified according to section 3.44.