

From: James Penney <james.penney@allenscott.co.uk>
Sent: 02 April 2025 09:21:24 UTC+01:00
To: "Rachel Richardson" <Rachel.Richardson@midsussex.gov.uk>
Cc: "Nicole Batten-Evatt" <nicole.batten-evatt@midsussex.gov.uk>; "Carol Beard" <Carol.Beard@midsussex.gov.uk>
Subject: RE: Mount Noddy Recreation Ground - Planning Conditions DM/25/0168
Attachments: 2025.03.25 Re: Mount Noddy Recreation ground - DM/25/0168 - DOC, GE21836 - Mount Noddy GAR OCT23.pdf

Dear Rachel,

I trust you are well.

RE: Mount Noddy Recreation Ground - Planning Conditions DM/25/0168

We understand that there was a query from the Flood Risk and Drainage Team on the Mount Noddy application (as attached), which we have discussed with the engineers and they have advised that;

- *An indicative falling head infiltration test was conducted during the site investigation, at which a rate of 6×10^{-6} m/s was recorded. This is deemed to be relatively poor, hence an alternative surface water discharge method was chosen in accordance with the surface water drainage hierarchy.*
- *We have attached the Site Investigation Report made by Geo-Environmental in this response.*

I trust this helps clarify but any other questions just let us know.

Best,

James Penney BSc(Hons), PgC, MLA, CMLI

Director



Allen Scott, 44 Newton Road,
Tunbridge Wells, Kent, TN1 1RU
T: +44 (0)1892 544 622
E: james.penney@allenscott.co.uk
www.allenscott.co.uk

The information contained in this message is intended only for the use of the individual or entity named above. If the reader of this message is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copying of this message is strictly prohibited. If you have received this message in error, please contact the sender and delete the material from any computer.