

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 01 April 2025 16:40:57 UTC+01:00
To: "Steven King" <Steven.King@midsussex.gov.uk>
Subject: DM/25/0804

Discharge of Conditions 6, 7 and 8 in relation to DM/24/0832

Hi Steve,

Condition 8 and 6: Looking at the original application, a 2m high close boarded timber fence is shown to the south facing perimeter of the padel courts. Speaking with Ollie who made comments at the time, this was the proposed acoustic barrier. Please can the applicants confirm that this structure has been provided. This acoustic fence is also mentioned in the NMP submitted.

Condition 7: Please can the applicant provide further details regarding the lighting scheme. What I am trying to establish is whether or not any residents in the immediate locality will be affected by the proposed lighting. I would consider this to be an E2 zone, and would therefore like to know the predicted illuminance (in lux), in the vertical plane at the windows of dwellings in the vicinity so that I can assess any impact from the lights.

Thanks,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk



"Working together for a better Mid Sussex"