

Anna Tidey

From: [REDACTED]
Sent: 13 June 2025 14:34
To: Anna Tidey
Cc: drainage
Subject: Re: DM/25/0240 (condition 11 of DM/23/2688) - Woodside Grange Woodland Road Hassocks West Sussex BN6 8EX
Attachments: FRA&D V4.pdf

For site B.

On 27 May 2025, at 17:29, Anna Tidey <anna.tidey@midsussex.gov.uk> wrote:


[REDACTED]
Please see below the comments that I have received from the MSDC Drainage Engineers today. They request further information is submitted for further consideration, before Condition 11 of DM/23/2688 can be discharged.

Regards
Anna

Submit your planning application online.
<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI
Planning Officer
Development Management

Tel: +44 (0)1444 477342
anna.tidey@midsussex.gov.uk <http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.

From: drainage <drainage@midsussex.gov.uk>
Sent: 27 May 2025 16:36
To: Anna Tidey <anna.tidey@midsussex.gov.uk>
Cc: drainage <drainage@midsussex.gov.uk>
Subject: 2027.05.27 Re: DM/25/0240 (condition 11 of DM/23/2688) - Woodside Grange Woodland Road Hassocks West Sussex BN6 8EX- Internal MSDC communications only

Dear Anna,

We consider that insufficient information has been provided to discharge this Condition.

Surface Water

The applicant proposes to manage surface water drainage from the development via an attenuation pond which discharges at an attenuated rate into the ditch located to the west of the site. No calculations have been presented which demonstrate that the pond is sufficiently sized. All calculations need to use a 45% climate change allowance. Details need to be provided for the outfall pipework from the attenuation pond to the ditch. Outfall details into the ditch should be provided.

The attenuation pond will require a 0.3m freeboard above the peak modelled water level.

Foul Water

Foul water drainage is proposed to connect into a foul sewer. This is considered acceptable in principle. The proposed surface water drainage strategy and foul water drainage information from the Taylor Wimpey foul plan should be shown on the same layout. It is also not clear on the Taylor Wimpey foul drainage plan how the proposed swimming pool is to be integrated into the system.

Following receipt of the additional information requested, we shall review and provide further comments on this application. Receipt of the requested additional information does not mean further information will not be requested.

If it is found post planning that this development cannot connect into the Taylor Wimpey drainage network, then the flood risk and drainage team will need to be consulted on any amended strategy.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk

of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.