

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 15 September 2025 11:20:56 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Subject: DM/25/1868 - 50 Hurst Road, Hassocks

Dear Anna,

I have reviewed the Arboricultural Impact Assessment (AIA) for this application.

I note that some of the trees are being relocated to facilitate this development, but that these are category C and not a constraint to development.

Further the two category B trees, which could be a constraint to development will be adequately protected during construction and the proposal is to be constructed outside of the Root Protection Area of these trees.

Provided that the measures presented in the Tree Protection Plan are adhered to, these trees should remain unharmed.

I have no objection to the proposal, but please do condition the AIA and TPP.

Kind regards

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex