

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 15 September 2025 11:05:00 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Subject: DM/25/1860 - Mount Farm, Albourne

Dear Anna,

In light of the new information provided, regarding the ground screw method to support the base of the garden room, I have no objection and do not require a full Tree Report.

The damage that these ground screws will cause to the root system is minimal and within the tolerances accepted in BS5837 - Tree is relation to design, demolition, and construction – Recommendations.

Kind regards

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex