

Mid Sussex District Council
Development Control
Oaklands Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Our ref: HA/2025/127096/03-L01
Your ref: DM/25/2853

Date: 23 December 2025

Dear Sir/Madam

**DISCHARGE OF CONDITION NO 6 RELATING TO PLANNING APPLICATION
DM/25/1753**

**TANYARD MANOR, HORSTED LANE, SHARPTHORNE, EAST GRINSTEAD,
WEST SUSSEX, RH19 4HY.**

Thank you for consulting the Environment Agency on the above application.
We have reviewed the information as submitted and set out our position below.

Environment Agency position

With regard to the clarification by email (dated 17 December 2025) advising a maximum pit depth for the tank of 1.55m and maximum trench depth of 0.75m, we are satisfied that Condition 6 can be discharged as it relates to matters within our remit.

If you have any queries regarding the above information, please do not hesitate to contact the advisor identified below.

Yours faithfully,

Environment Agency – Solent & South Downs

Sustainable Places Advisor: John Fanning
Direct e-mail: John.Fanning@environment-agency.gov.uk