



FAO Carl Delacruz
Strickland Wright

Dear Carl

9th July 2026

Wykehurst House – Amended Cable Route.

Having reviewed the existing electrical engineering drawing showing the routing and provided a revised suggested route which avoids the root protection areas of all trees, I am confident that the route will avoid damage to the existing trees. As the route now avoids all root protection areas, the potential for root damage during excavation should be minimal if not non-existent and complies with guidance as set out in BS5837:2012 Trees in relation to design, demolition and construction – Recommendations. Additional tree protection fencing will be required to protect the root protection areas from being tracked over by the plant undertaking the excavation, and a further tree protection plan showing the location of the fencing can be produced once the revised electrical engineering drawing is finalised.

If you have any queries regarding the above, please don't hesitate to contact me.

Yours sincerely

A handwritten signature in black ink that reads 'Nick Betts'.

Nick Betts
HND For. M.Arbor.A
Senior Arboriculturalist