

Design Settings

Rainfall Methodology	FEH-22	Minimum Velocity (m/s)	1.00
Return Period (years)	2	Connection Type	Level Soffits
Additional Flow (%)	0	Minimum Backdrop Height (m)	0.200
CV	1.000	Preferred Cover Depth (m)	1.200
Time of Entry (mins)	5.00	Include Intermediate Ground	✓
Maximum Time of Concentration (mins)	30.00	Enforce best practice design rules	✓
Maximum Rainfall (mm/hr)	50.0		

Nodes

Name	Area (ha)	T of E (mins)	Cover Level (m)	Diameter (mm)	Depth (m)
S1	0.044	5.00	108.200	450	2.000
S2			107.200	600	1.200
S3			107.000	600	1.050

Links

Name	US Node	DS Node	Length (m)	ks (mm) / n	US IL (m)	DS IL (m)	Fall (m)	Slope (1:X)	Dia (mm)	T of C (mins)	Rain (mm/hr)
1.000	S1	S2	20.000	0.600	106.200	106.000	0.200	100.0	150	5.33	50.0
1.001	S2	S3	5.000	0.600	106.000	105.950	0.050	100.0	150	5.41	50.0

Name	Vel (m/s)	Cap (l/s)	Flow (l/s)	US Depth (m)	DS Depth (m)	Σ Area (ha)	Σ Add Inflow (l/s)	Pro Depth (mm)	Pro Velocity (m/s)
1.000	1.005	17.8	8.0	1.850	1.050	0.044	0.0	71	0.979
1.001	1.005	17.8	8.0	1.050	0.900	0.044	0.0	71	0.979

Simulation Settings

Rainfall Methodology	FEH-22	Analysis Speed	Normal	Additional Storage (m³/ha)	20.0
Summer CV	1.000	Skip Steady State	x	Check Discharge Rate(s)	x
Winter CV	1.000	Drain Down Time (mins)	240	Check Discharge Volume	x

Storm Durations

15	30	60	120	180	240	360	480	600	720	960	1440
----	----	----	-----	-----	-----	-----	-----	-----	-----	-----	------

Return Period (years)	Climate Change (CC %)	Additional Area (A %)	Additional Flow (Q %)
100	40	0	0

Node S2 Online Orifice Control

Flap Valve	x	Design Depth (m)	0.400	Discharge Coefficient	0.600
Replaces Downstream Link	✓	Design Flow (l/s)	1.5		
Invert Level (m)	106.000	Diameter (m)	0.034		

Node S1 Depth/Area Storage Structure

Base Inf Coefficient (m/hr)	0.00000	Safety Factor	2.0	Invert Level (m)	106.200
Side Inf Coefficient (m/hr)	0.00000	Porosity	0.90	Time to half empty (mins)	126



VKHP Consulting Ltd
340 High Street
Dorking
Surrey, RH14 1QX

File: 683826 - 02.pfd
Network: Storm Network
Andrew Bird
02/04/2026

Page 2
Jeremys Cottage
Bolney
Haywards Heath

Depth (m)	Area (m ²)	Inf Area (m ²)	Depth (m)	Area (m ²)	Inf Area (m ²)	Depth (m)	Area (m ²)	Inf Area (m ²)
0.000	60.0	0.0	0.400	60.0	0.0	0.401	0.0	0.0

Results for 100 year +40% CC Critical Storm Duration. Lowest mass balance: 99.30%

Node Event	US Node	Peak (mins)	Level (m)	Depth (m)	Inflow (l/s)	Node Vol (m³)	Flood (m³)	Status
120 minute winter	S1	112	106.625	0.425	11.1	21.8817	0.0000	SURCHARGED
120 minute winter	S2	112	106.623	0.623	1.9	0.1762	0.0000	SURCHARGED
15 minute summer	S3	1	105.950	0.000	1.6	0.0000	0.0000	OK

Link Event (Outflow)	US Node	Link	DS Node	Outflow (l/s)	Velocity (m/s)	Flow/Cap	Link Vol (m³)	Discharge Vol (m³)
15 minute winter	S1	1.000	S2	6.6	0.545	0.370	0.3521	
120 minute winter	S2	Orifice	S3	1.9				30.3