

Delegated Decision

Sign off Sheet

Ref. No:	DM/26/1272	Case Officer:	Susan Dubberley
Application Type:	Overhead Electricity Line		
Proposal:	Downing and relocation of overhead HV pole. UKPN to complete 1x 11kV HV pole termination at new terminal pole following the diversion of pole 614327 for the establishment of a new IDNO substation to connect a new load. Proposal is to connect the new substation into the 11 feeder from East Grinstead 33/11kV primary as a teed connection at diverted HV pole 614327.		
Site:	Ibstock Kevington Building Products Ltd, Ibstock Brick West Hoathly, Hamsey Road, Sharpthorne, East Grinstead, West Sussex, RH19 4PB,		
Validation Date	20 May 2026	Overall Expiry Date:	
Pre-Commencement Conditions Required:		Pre-Com Conditions Date Agreed:	
Recommendation:	No Objection	Recommendation Date:	16 Jun 2026
Target Date:	1 Jul 2026	Recommending Officer Signature:	<i>Susan Dubberley</i>

Date Legal Agreement Completed: (if applicable)		No of Representations:	0
--	--	-------------------------------	---

Signed and Agreed By:	<i>Steven King</i>	Date:	16 Jun 2026
Comments:			

MID SUSSEX DISTRICT COUNCIL

DM/26/1272

**Ibstock Kevington Building Products Ltd, Ibstock Brick West Hoathly, Hamsey Road,
Sharpthorne, East Grinstead, West Sussex, RH19 4PB**

**Downing and relocation of overhead HV pole. UKPN to complete 1x 11kV HV pole termination at
new terminal pole following the diversion of pole 614327 for the establishment of a new IDNO
substation to connect a new load.**

**Proposal is to connect the new substation into the 11 feeder from East Grinstead 33/11kV
primary as a teed connection at diverted HV pole 614327.**

Emily Haikney

Decision: No Objection

Case Officer: Susan Dubberley