

From: Lap Chan <lapchan2010@hotmail.co.uk>
Sent: 15 June 2026 09:12:27 UTC+01:00
To: "Caroline Grist" <Caroline.Grist@midsussex.gov.uk>
Cc: "James Smith" <james.smith@lewes-eastbourne.gov.uk>
Subject: Re: DM/25/2071: Land to Rear Of Chideok, Valebridge Road, Burgess Hill
Attachments: 26005-HOD-XX-XX-RP-C-5801-Z03 FRA.pdf

Morning Caroline

Hope you are well.

Please find attached the revised FRA that we have received from our drainage consultant in response to the comments that you forwarded from your Drainage Engineer.

Should you have any queries, please do not hesitate to contact me.

Regards

Lap

From: Caroline Grist <Caroline.Grist@midsussex.gov.uk>
Date: Wednesday, 27 May 2026 at 15:40
To: Lap Chan <lapchan2010@hotmail.co.uk>
Cc: James Smith <james.smith@lewes-eastbourne.gov.uk>
Subject: RE: DM/25/2071: Land to Rear Of Chideok, Valebridge Road, Burgess Hill

Dear Lap,

Please find attached to this email the comments from our Drainage Engineer to the response provided from your drainage engineer. I am sorry for the delay in sending you this email.

As set out in their comments, the information provided is not sufficient to overcome the previously raised concerns and the objection therefore remains. Further guidance is also provided in this response.

A response that provides the information sought by our Drainage Engineer would therefore be required to progress this application.

Please can you advise how you would wish to proceed,

Kind regards,
Caroline

Caroline Grist
Senior Planning Officer
Development Management

Mid Sussex District Council
01444 477333
caroline.grist@midsussex.gov.uk
www.midsussex.gov.uk



Working together for a better Mid Sussex

From: Caroline Grist
Sent: 07 May 2026 11:22
To: 'Lap Chan' <lapchan2010@hotmail.co.uk>
Cc: James Smith <james.smith@lewes-eastbourne.gov.uk>
Subject: RE: DM/25/2071: Land to Rear Of Chideok, Valebridge Road, Burgess Hill

Dear Lap,

Thank you for the email confirming, it is much appreciated.

Kind regards,
Caroline

Caroline Grist
Senior Planning Officer
Development Management

Mid Sussex District Council
01444 477333
caroline.grist@midsussex.gov.uk
www.midsussex.gov.uk



Working together for a better Mid Sussex

From: Lap Chan <lapchan2010@hotmail.co.uk>
Sent: 07 May 2026 09:26
To: Caroline Grist <caroline.grist@midsussex.gov.uk>
Cc: James Smith <james.smith@lewes-eastbourne.gov.uk>
Subject: Re: DM/25/2071: Land to Rear Of Chideok, Valebridge Road, Burgess Hill

Morning Caroline

Yes. That's fine. We agree to an extension until 12th June.

Regards

Lap

From: Caroline Grist <caroline.grist@midsussex.gov.uk>
Date: Wednesday, 6 May 2026 at 16:31
To: Lap Chan <lapchan2010@hotmail.co.uk>
Cc: James Smith <james.smith@lewes-eastbourne.gov.uk>
Subject: RE: DM/25/2071: Land to Rear Of Chideok, Valebridge Road, Burgess Hill

Dear Lap,

Thank you for email, which I have forwarded to our Drainage Engineers for consideration.

The standard time frame for consultees to respond is 21 days. Would it therefore be acceptable to agree an extension of time until Friday 12th June to allow for this and next steps to be taken please?

Kind regards,
Caroline

Caroline Grist
Senior Planning Officer
Development Management

Mid Sussex District Council
01444 477333
caroline.grist@midsussex.gov.uk
www.midsussex.gov.uk



Working together for a better Mid Sussex

From: Lap Chan <lapchan2010@hotmail.co.uk>
Sent: 29 April 2026 14:01
To: Caroline Grist <caroline.grist@midsussex.gov.uk>

Cc: James Smith <james.smith@lewes-eastbourne.gov.uk>

Subject: DM/25/2071: Land to Rear Of Chideok, Valebridge Road, Burgess Hill

Hi Caroline

Hope you are well.

Further to your recent correspondence dated 14/04/2026, regarding the above planning application, please find below the response that we have received from our drainage engineer in response to the concerns that were raised by the Local Authority Drainage Engineer.

Can you please pass this response onto the Local Authority Drainage Engineer to see if these actions would alleviate their concerns?

Regards

Lap

From: Jim Hilder <jhilder@hodel.uk>

Date: Wednesday, 29 April 2026 at 10:03

To: Lap Chan <lapchan2010@hotmail.co.uk>

Cc: Paul Holland <paulholland6@icloud.com>, James Bowtell <james@vanderhomes.com>

Subject: Re: DM/25/2071: Land to Rear Of Chideok, Valebridge Road, Burgess Hill

Hi Lap,

Apologies for the delayed response, it has taken a little time to consider an appropriate response.

Dear Sirs,

Thank you for your consultation response in relation to application DM/25/2071.

We note that Mid Sussex District Council's comments relate specifically to the proposed access/driveway, which lies within your administrative boundary, and we acknowledge your recommendation that the wider development be considered by the East Sussex Lead Local Flood Authority.

In reviewing your response, we would respectfully clarify that the classification of areas of surface water flood risk as equivalent to Flood Zone 3b (functional floodplain) is not explicitly defined within national policy or guidance. The Planning Practice Guidance supporting the Ministry of Housing, Communities and Local Government framework distinguishes functional floodplain primarily in relation to fluvial and tidal processes. While surface water risk is clearly an important consideration, its direct equivalence to Flood Zone 3b is not typically applied in policy terms.

Notwithstanding the above, we acknowledge the mapped surface water flow path crossing the site and the need to ensure that the proposed access does not impede flow routes or give rise to increased flood risk.

To address this, our client is happy to provide the following:

- raise the finished level of the driveway above the surrounding ground by 350mm to improve resilience to shallow overland flow; and
- incorporate appropriately sized culvert pipes beneath the access, laid at the existing ground level to maintain the existing surface water flow path and avoid obstruction of flood routing.

This approach is intended to ensure that:

- exceedance flows can continue to pass through the site without restriction;
- flood risk is not increased elsewhere; and
- safe access and egress can be maintained during rainfall events, where practicable.

We also note your comments regarding the absence of surface water drainage details. A proportionate drainage strategy will be prepared to ensure runoff from the access will be managed in accordance with sustainable drainage principles.

We trust that the above demonstrates a willingness to address the concerns raised in a proportionate and technically robust manner.

Kind regards,

Jim Hilder
Director



Hodel Ltd, The Gate House, Bays 2&3, Pattenden Lane
Marden, Tonbridge. TN12 9QS
01732 617555
07855 786475
jhilder@hodel.uk

Upcoming Leave: -

Hodel Ltd.
Registered in England and Wales. Registered Number: 9919584. Registered Office: The Coach House, 1 Howard Road, Reigate, RH2 7JE.

This email and any attachments are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the sender immediately and delete it from your system. Any unauthorised use, disclosure, copying or distribution is prohibited.

Although Hodel Ltd has taken reasonable precautions to ensure no viruses are present in this email, the company cannot accept responsibility for any loss or damage arising from the use of this email or attachments.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.