

Delegated Decision

Sign off Sheet

Ref. No:	DM/25/0414	Case Officer:	Peter Davies
Application Type:	Overhead Electricity Line		
Proposal:	Reinforcement of high voltage overhead lines involving reconductoring and addition of a third wire between poles 616012 and 616017 (3 spans). Pole 616015 is to be relocated to amend span lengths to support the increased conductor weight. Pole 616012 requires an additional stay wire and realignment of existing stay. A new pole is to be installed alongside Pole 616017 to create an H-Pole with 2 stays to support an upgraded pole-mounted transformer. (PMT). The low voltage overhead lines between 616017 and 633238 are to be replaced with aerial bundled cables (ABC). Poles 616016, 616017, 633216, 633227, 633232 and 633236 to be replaced in same locations. Stays to be replaced on 633229 and 633230, 633233, 633234.		
Site:	Land Adj. To High Coombe House, Private Road, Balcombe, Haywards Heath, West Sussex, RH17 6PS, ,		
Validation Date	17 Feb 2025	Overall Expiry Date:	
Pre-Commencement Conditions Required:		Pre-Com Conditions Date Agreed:	
Recommendation:	No Objection	Recommendation Date:	4 Mar 2025
Target Date:	31 Mar 2025	Recommending Officer Signature:	Peter Davies

Date Legal Agreement Completed: (if applicable)		No of Representations:	0
---	--	------------------------	---

Signed and Agreed By:	Joanne Fisher	Date:	5 Mar 2025
Comments:			

--	--

MID SUSSEX DISTRICT COUNCIL

DM/25/0414

Land Adj. To High Coombe House, Private Road, Balcombe, Haywards Heath, West Sussex, RH17 6PS,

Reinforcement of high voltage overhead lines involving reconductoring and addition of a third wire between poles 616012 and 616017 (3 spans). Pole 616015 is to be relocated to amend span lengths to support the increased conductor weight.

Pole 616012 requires an additional stay wire and realignment of existing stay. A new pole is to be installed alongside Pole 616017 to create an H-Pole with 2 stays to support an upgraded pole-mounted transformer. (PMT). The low voltage overhead lines between 616017 and 633238 are to be replaced with aerial bundled cables (ABC). Poles 616016, 616017, 633216, 633227, 633232 and 633236 to be replaced in same locations. Stays to be replaced on 633229 and 633230, 633233, 633234.

Charlotte Cole

Decision: No Objection

Case Officer: Peter Davies