



HAZARD WARNING SCHEDULE	
HAZARD	COMMENT/ACTION
Service Vehicles and Deliveries	Close proximity to neighbouring school, church and residential properties will require a safe method of stationing to be provided and appropriate actions taken to ensure safe manoeuvring when accessing site. Liaison required with school management prior to any working commencing.
Roof Access and maintenance	Appropriate access and edge protection to be provided to allow roof access to maintain PV. Sufficient hand holding and ground level to be provided to allow safe climb of cherry picker. Rear gutter to be cleaned and maintained from MEWP at ground level.
Noise and disturbance to neighbours	All work to be carried out within agreed working hours in order to limit disturbance to neighbours.
Risks associated with	Risks intrinsic to Lidl's store model are provided in document

PROPOSED GA ELEVATIONS							
DRAWING STATUS							
TENDER							
DRAWN	MBN			CHECKED	WF		
SCALE	AS SHOWN @ A0						
DATE	03/09/24						
				Chesterfield / 01246 206081 London / 020 3388 0019 Leeds / 01114 488 2450 whittamcox.com			
Project	Originator	Volume	Level	Type	Risk	Number	Revision