

From: drainage <drainage@midsussex.gov.uk>
Sent: 17 December 2025 13:10:02 UTC+00:00
To: "Andrew Clarke" <Andrew.Clarke@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2025.12.17 Re: DM/25/2123 - Cuckfield Golf Course Staplefield Road Cuckfield Haywards Heath West Sussex RH17 5HY

Dear Andrew,

The Flood Risk and Drainage Team have reviewed the updated information and have the following comments.

Confirmation should be provided of the surface water drainage arrangements for any proposed hardstanding/ impermeable areas.

For consistency, the calculations and layout should be updated to ensure all information is consistent, including pipe numbers.

Upon receipt of this additional information, we will be able to comment further.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk