

Our Ref: 8500321253

Planning Office
Mid Sussex District Council
Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Also sent by email to
servicesupport@midsussex.gov.uk
planninginfo@midsussex.gov.uk

22nd September 2025

Dear Sir/Madam

Electricity Act 1989
Overhead Line (Exemption) (England & Wales) Regulations 2009
Statutory Instrument 2009 No. 640 Electricity, Paragraph 3 (1)

This notice is being given to your Council under The Overhead Lines (Exemption) (England & Wales) Regulation 2009.

Under this exemption, your Authority is required to determine, within 6 weeks of receipt of this notice, whether it is considered that the proposal is likely to have a significant adverse effect on the environment.

The works associated with this proposal will commence on site on or after the expiry of the required six weeks notice, unless it becomes necessary to apply to the Secretary of State for Trade and Industry for his consent.


Particulars of proposal:

Location: Bowders Farm, Haywards Heath Road, Balcombe, Haywards Heath, RH17 6QH


Plan No: UKPN 8500321253-1-500_UPDATED2

Details of proposal:

- To install 2 new stay wires on pole 615576. 3 existing stays on this pole will be removed.
- To replace HV poles 615577 and 615564 with stout poles.



Stessie Aristide
Connections Surveyor
South Eastern Power Networks plc



Return Address:
South Eastern Power Networks plc
Property & Consents
c/o Energy House
Hazelwick Avenue
Three Bridges
Crawley
RH10 1EX