

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 03 April 2025 14:52:15 UTC+01:00
To: "Andrew Horrell" <Andrew.Horrell@midsussex.gov.uk>
Subject: DM/25/0437 The Beaumont, 8 Ockley Lane, Hassocks

Dear Andy,

I have reviewed the Tree Report for this proposal and find that it is not adequate.

It does not categorise the trees, nor does it state for definite what species the trees are. It does not give any detail of the percentage of RPA incursions or whether any of the trees will be pruned/ felled to facilitate the proposal. There is no methodology or Tree Protection Plan, to reassure me that the trees will be protected during construction and that they roots will not be impacted by the proposal.

Please could you request further detail in the form of an Arboricultural Impact Assessment, including a Tree Protection Plan and Arboricultural Method Statement?

Please reconsult me once this has been received.

Kind regards

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex