

Anna Tidey

From: [REDACTED]
Sent: 05 March 2026 15:48
To: Anna Tidey
Cc: Emily Wade
Subject: RE: DM/25/2662 & 3 - The Toll House, High Street, Lindfield
Attachments: 56HS-001-C-039_01 Section 2nd Floor Window.pdf; 56HS-001-C-010_01 Elevation From West.pdf; 56HS-001-C-034_02 Section Bifold Window.pdf; 56HS-001-C-035_02 Section Sliding Door.pdf; Response for Discharge Conditions 2026-03-05.docx

Hi Anna, thank you for your email.

Please find all details requested attached.

Thank you.

From: Anna Tidey <anna.tidey@midsussex.gov.uk>

Sent: 05 March 2026 12:27

[REDACTED]
Cc: Emily Wade <Emily.Wade@midsussex.gov.uk>

Subject: Re: DM/25/2662 & 3 - The Toll House, High Street, Lindfield

Dear Mr Perez

I am reviewing your planning files for the above, having received a reply from Emily Wade today, see below.

I am sorry but it appears that I did not send her comments dated 12.02.2026, also attached below, on to you. I sincerely apologise for the delay.

I note that some of the material submissions that you have provided are acceptable to Emily. For simplicity I will await further details rather than partly discharging the planning conditions. This will require the elements that Emily has detailed to be addressed.

I therefore hope that you can provide the following:

Condition 3- Roofing and facing materials

Please provide the roof slate details – ie, manufacturer/supplier, range and colour.

Please confirm the actual reclaimed brick to be used and the colour match.

Condition 6 Windows and attic windows, eaves detail, internal and external doors

Windows and attic windows

Please provide details of the materials for the bifold windows.

Please provide details of the attic window to the front elevation – ie, large scale elevations and sections.

External doors


Please provide details of the materials.

I look forward to receiving the additional details from you.
Thank you for your attention to this matter.
Kind regards
Anna

Submit your planning application online.
<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI
Planning Officer
Development Management

Tel: +44 (0)1444 477342
anna.tidey@midsussex.gov.uk <http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.



- SAVE A TREE Only print this email if absolutely necessary.

From: Emily Wade <Emily.Wade@midsussex.gov.uk>
Sent: 05 March 2026 09:52
To: Anna Tidey <anna.tidey@midsussex.gov.uk>
Subject: RE: The Toll House, High Street, Lindfield DM/25/2663

Hi Anna

I am just looking at this one but I am confused- I sent comments on 12th Feb (below), and I can't see any further info on file or in my inbox after this date. If there are new plans to look at can you point me towards them please?


Thanks,

Emily

Please note that this advice is given at Officer level only and is without prejudice to the formal decision of the District Council.

Submit your planning application online.
<http://www.planningportal.gov.uk>

Emily Wade Ma MSc
Conservation Officer
Planning Services



From: Emily Wade
Sent: 12 February 2026 16:37
To: Anna Tidey <anna.tidey@midsussex.gov.uk>
Subject: The Toll House, High Street, Lindfield DM/25/2663

Hi Anna

Further comments on the above discharge of conditions application.

Condition 3- Roofing and facing materials

I can't at present see any details of the roof slate? We would need manufacturer/supplier, range and colour.

With respect to the brick, the applicant has provided three different images. Although I don't have a problem with the approach outlined the reclaimed bricks shown do not appear to be a particularly good match for the existing? They appear much lighter in colour.

Condition 5 - Window and door openings, including window and door heads

The detail provided is acceptable.

Condition 6 Windows and attic windows, eaves detail, internal and external doors

Windows and attic windows

We have sectional details of the bifold windows, but I believe we previously asked for details of the material and this does not appear to have been provided.

We have no further details of the attic window to the front elevation as far as I can see? Large scale elevations and sections should be provided.

The eaves detail as shown is not a traditional detail, and is not in my opinion particularly sympathetic to the context. However given that this is a contemporary addition I consider on balance that an objection could not be sustained.

Internal doors as previously noted are acceptable.

External doors As above for the bifolds, we have only sectional details of the sliding doors as far as I can see.

Thanks,

Emily

Please note that this advice is given at Officer level only and is without prejudice to the formal decision of the District Council.

Submit your planning application online.
<http://www.planningportal.gov.uk>

Emily Wade Ma MSc
Conservation Officer
Planning Services
Tel: +44 (0)1444 477385
emily.wade@midsussex.gov.uk <http://www.midsussex.gov.uk>



The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.