

Delegated Decision

Sign off Sheet

Ref. No:	DM/25/1530	Case Officer:	Andrew Horrell
Application Type:	Lawful Development Certificate -Proposed		
Proposal:	Hip to gable loft conversion with rear dormer.		
Site:	110 College Lane, Hurstpierpoint, Hassocks, West Sussex, BN6 9AJ, , ,		
Validation Date	16 Jun 2025	Overall Expiry Date:	8 Jul 2025
Pre-Commencement Conditions Required:		Pre-Com Conditions Date Agreed:	
Recommendation:	Permission	Recommendation Date:	5 Aug 2025
Target Date:	11 Aug 2025	Recommending Officer Signature:	Andrew Horrell

Date Legal Agreement Completed: (if applicable)		No of Representations:	0
--	--	-------------------------------	---

Signed and Agreed By:	Stephen Ashdown	Date:	6 Aug 2025
Comments:			

MID SUSSEX DISTRICT COUNCIL

DM/25/1530

**110 College Lane, Hurstpierpoint, Hassocks, West Sussex, BN6 9AJ, ,
Hip to gable loft conversion with rear dormer.
Adam Whitby**

INTRODUCTION

The application seeks a lawful development certificate for a hip to gable loft conversion with a rear dormer.

SITE AND SURROUNDINGS

110 College Lane is a two-storey semi-detached hipped roofed dwelling, the walls are a mix of face brickwork and painted render with aluminium and upvc doors and windows.

The dwelling is characterised by a single storey rear extension approved under DM/16/2508 and a two-storey side extension approved under HP/065/98.

APPLICATION DETAILS

The proposed plans show a hip to gable roof extension to allow for a rear dormer and four front rooflights. This will create a bedroom and an en-suite. A side rooflight to the first floor landing is proposed.

LIST OF POLICIES

As this is an application to establish whether the proposed development would benefit from permitted development rights and will be a legal decision, planning merits cannot be taken into account when considering this application.

The proposal will be tested against the relevant criteria of Part 1 Classes B and C of Schedule 2 of The Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended), as detailed below:

B. The enlargement of a dwellinghouse consisting of an addition or alteration to its roof.

Development Not Permitted

B.1 Development is not permitted by Class B if—

- (a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule;
- (b) any part of the dwellinghouse would, as a result of the works, exceed the height of the highest part of the existing roof;
- (c) any part of the dwellinghouse would, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway;
- (d) the cubic content of the resulting roof space would exceed the cubic content of the original roof space by more than—
 - (i) 40 cubic metres in the case of a terrace house, or
 - (ii) 50 cubic metres in any other case;
- (e) it would consist of or include—
 - (i) the construction or provision of a veranda, balcony or raised platform, or
 - (ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe; or

(f) the dwellinghouse is on article 2(3) land.

Conditions

B.2 Development is permitted by Class B subject to the following conditions—

- (a) the materials used in any exterior work shall be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;
- (b) the enlargement must be constructed so that -
 - (i) other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension -
 - (aa) the eaves of the original roof are maintained or reinstated; and
 - (bb) the edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2 metres from the eaves, measured along the roof slope from the outside edge of the eaves; and
 - (ii) other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse; and
- (c) any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse shall be—
 - (i) obscure-glazed, and
 - (ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

Interpretation of Class B

B.3 For the purposes of Class B "resulting roof space" means the roof space as enlarged, taking into account any enlargement to the original roof space, whether permitted by this Class or not.

B.4 For the purposes of paragraph B.2(b)(ii), roof tiles, guttering, fascias, barge boards and other minor roof details overhanging the external wall of the original dwellinghouse are not to be considered part of the enlargement.

C. Any other alteration to the roof of a dwellinghouse.

Development Not Permitted

C.1 Development is not permitted by Class C if—

- (a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use);
- (b) the alteration would protrude more than 0.15 metres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original roof;
- (c) it would result in the highest part of the alteration being higher than the highest part of the original roof; or
- (d) it would consist of or include—
 - (i) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or
 - (ii) the installation, alteration or replacement of solar photovoltaics or solar thermal equipment.

Conditions

C.2 Development is permitted by Class C subject to the condition that any window located on a roof slope forming a side elevation of the dwellinghouse must be—

- (a) obscure-glazed; and
- (b) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

ASSESSMENT

The site is not within article 2(3) land or subject to an Article 4 direction. The Planning history has been checked. Permitted development rights are deemed intact for this type of development.

The proposed hip to gable loft conversion with a rear dormer has been calculated to measure circa 34 cubic metres in volume (Hip to gable 14.4 and rear dormer 22.6). Coupled with this, the existing side extension having a volume of 11.4 cubic metres, therefore an enlargement of 48.4 cubic metres which is less than the 50 cubic metre volume allowed for this type of dwelling.

The site is not situated on article 2(3) land. It will not have any part of the dwellinghouse as a result of the works, exceed the height of the highest part of the existing roof or that any part of the dwellinghouse would, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway.

The elevation drawings outline that the materials used for the loft conversion dormer will be similar in appearance to those used in the existing dwelling.

The proposed rooflights will not protrude more than 0.15 metres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original roof and would not result in the highest part of the alteration being higher than the highest part of the original roof and no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse.

CONCLUSION

Therefore, in conclusion, the proposed development is deemed to comply with the applicable permitted development criteria as set out within Classes B and C of Part 1 to Schedule 2 of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended) and therefore a certificate can be issued.

Decision: Permission

Case Officer: Andrew Horrell