

From: drainage <drainage@midsussex.gov.uk>
Sent: 12 June 2026 10:13:30 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.06.12 RE: DM/26/1046 - Land Adj The Meadows, Little Park Farm, Hurstpierpoint, BN6 9UZ

Dear Anna,

The flood risk and drainage team have reviewed the updated information and have the following comments:

The proposed area of the attenuation basin should be considered within the drainage calculations. The resized attenuation basin should ensure that a minimum freeboard allowance of 300mm is incorporated into the detention basin design, given that an open drainage feature is proposed.

Upon receipt of this additional information, we will be able to comment further.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk