

Mid Sussex District Council
Development Control
Oaklands Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Our ref: HA/2026/127398/01-L01
Your ref: DM/25/3023
Date: 15 January 2026

Dear Sir/Madam

REPLACEMENT GARAGE AND TWO STOREY SIDE EXTENSION TO THE EAST. NEW ROOF LIGHT TO SOUTH ELEVATION. NEW FRENCH DOORS TO SOUTH ELEVATION REPLACING EXISTING SINGLE DOOR. REPLACEMENT OF BAY WINDOW TO THE WEST ELEVATION AND EXTENDING TO THE FIRST FLOOR.

2 BY SUNTE LINDFIELD HAYWARDS HEATH WEST SUSSEX RH16 2DF

Thank you for consulting the Environment Agency on the above application. We have reviewed the information as submitted and set out our position below.

Environment Agency position

We have **no objection to the proposed development as submitted, provided that the following condition be attached** to any planning permission granted, and that the details in relation to this condition be submitted and approved by the Local Planning Authority.

Condition – Flood Risk Assessment

The development shall be carried out in accordance with the submitted flood risk assessment (dated February 2025) and the following mitigation measures it details:

- Proposed finished floor levels of the extension shall be set no lower than existing floor levels

These mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the scheme's timing/phasing arrangements. The measures detailed above shall be retained and maintained thereafter throughout the lifetime of the development.

Reason(s)

- To reduce the risk of flooding to the proposed development and future occupants

Advice to applicant

Environmental permit

The Environmental Permitting (England and Wales) Regulations 2016 require a permit or exemption to be obtained for any activities which will take place:

- on or within 8 metres of a main river (16 metres if tidal)
- on or within 8 metres of a flood defence structure or culverted main river (16 metres if tidal)
- on or within 16 metres of a sea defence
- involving quarrying or excavation within 16 metres of any main river, flood defence (including a remote defence) or culvert
- in the floodplain of a main river if the activity could affect flood flow or storage and potential impacts are not controlled by a planning permission

For further guidance please visit <https://www.gov.uk/guidance/flood-risk-activities-environmental-permits> or contact our National Customer Contact Centre on 03708 506 506 (Monday to Friday, 8am to 6pm) or by emailing enquiries@environment-agency.gov.uk.

The applicant should not assume that a permit will automatically be forthcoming once planning permission has been granted, and we advise them to consult with us at the earliest opportunity.

If you have any queries regarding the above information, please do not hesitate to contact the advisor identified below.

Yours faithfully,

Environment Agency – Solent & South Downs

Sustainable Places Advisor: John Fanning
Direct e-mail John.Fanning@environment-agency.gov.uk