

Anna Tidey

From: [REDACTED]
Sent: 10 July 2025 16:52
To: Anna Tidey
Cc: drainage
Subject: Re: 2025.07.01 Re: DM/25/0240 – Reference DOC 11 - Woodside Grange
Woodland Road Hassocks West Sussex BN6 8EX
Attachments: FRA&D Site A V6.pdf

You don't often get email from a [REDACTED]. [Learn why this is important](#)

Anna - hope all good.

In response to the last email. Please find an updated flood report V6, that i hope answers the latest requests for Drainage team. My consultant had tried to contact the team to discuss but didn't hear back. So we have submitted according to the comments in the thread below.

Please let me know asap if this is satisfactory.

Thanks in advance.

Tony

Below are her comments in blue.

I have revised the drainage design again. The plans are now merged with the Taylor Wimpey sewer plans in Appendix C, I have included a cross section of the pond and diagrams of the pipework and vortex valve in the report. I have stated that the tennis court is existing and not included in the design and that it is permeable and included a calculation to show how the attenuation is sized. I hope that is everything that they want. Please find it attached.

Dear Tony

I have just received this response from the Drainage section.

I am sorry but Condition 11 remains outstanding


Regards

Anna

Submit your planning application online.
<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI
Planning Officer
Development Management

Tel: +44 (0)1444 477342
anna.tidey@midsussex.gov.uk <http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.



- SAVE A TREE Only print this email if absolutely necessary.

From: drainage <drainage@midsussex.gov.uk>
Sent: 03 July 2025 15:44
To: Anna Tidey <anna.tidey@midsussex.gov.uk>
Cc: drainage <drainage@midsussex.gov.uk>
Subject: 2025.07.01 Re: DM/25/0240 – Reference DOC 11 - Woodside Grange Woodland Road Hassocks West Sussex BN6 8EX

Dear Anna,

We consider that insufficient information has been provided to discharge this Condition. Please note that the Flood Risk and Drainage Team have only commented/ been commenting on the information relevant to condition 11 of DM/23/2688 (Site A).

Surface Water

The applicant proposes to manage surface water drainage from the development via an attenuation pond which discharges at an attenuated rate into the ditch located to the west of the site.

All attenuation features should be located within the application boundary.

Confirmation should be provided that the area of the attenuation pond itself has been considered within the drainage calculations.

Details have still not been provided relating to the outfall into the ditch or the outfall pipework from the attenuation pond to the ditch.

It is no longer clear on the drainage layout how the existing tennis court will be drained. Details need to be provided.

A cross section of the attenuation pond should be provided to demonstrate how the required attenuation volume and freeboard are provided.

Following receipt of the additional information requested, we shall review and provide further comments on this application. Receipt of the requested additional information does not mean further information will not be requested.

Foul Water

Foul water drainage is proposed to connect into a foul sewer. This is considered acceptable in principle.

The foul water drainage information shown on in appendix D (proposed attenuation drainage design), differs from that shown in appendix E (Taylor Wimpey sewer and drainage plans). The information provided should be consistent.

Following receipt of the additional information requested, we shall review and provide further comments on this application. Receipt of the requested additional information does not mean further information will not be requested.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.