

 UK Power Networks POLE SCHEDULE																		
JOB No	Job Title				ROUTE LENGTH	LS DRAWING No			SHEET			CONDUCTOR	SPECIFICATION	SURVEYED BY	DATE			
ISSUE A	OVERHEAD LINE UPGRADE, HIGH COOMBE HOUSE				0.62 KM	02-240954-02			1 OF 1			50mm AAAC & 4x 120mm ABC	OHL MANUAL SECT 3 & SECT 1	LSTC	19-Nov-24			
POLE				SPAN (M) (Behind)	ANGLE OF DEVIATION	INSULATORS			STAYS (GRADE 1150)			WAYLEAVES		OWNER NAME & ADDRESS	OCCUPIER NAME & ADDRESS	NOTES	DRAWING No	
No	TYPE	HEIGHT (M)	DIAM (mm)			PIN	PILOT	STRN	No	SIZE	SPRD	BLOCK	POLE					STAY
11kV - 50mm AAAC HAZEL					(EDF Overhead Lines Construction Manual Section 3 (11-33kV Bare 2010))													
616012	INTER TEE	11	295 (S)	-	TEE	3		3	2	7/4.	4.8m						EXISTING POLE, REPLACE TEE OFF XARM REPLACEMENT STAYS	
616015	SECTION	11	295 (S)	89.08			1	6				2					NEW POLE	FIG 5
616016	INTER	11	295 (S)	72.08		3						2					REPLACEMENT POLE	FIG 1
161017	TERMINAL	11	295 (S)	85.12	TERM			3	2	7/4.	5.3m	2					REPLACEMENT POLE & STAYS, ADD STUB LEG, NEW 200kVA PMT, LV O/H OFF 2xLV FUSES	FIG 8
LV - 4x120mm ABC					(EDF Overhead Lines Construction Manual Section 1 (LV-ABC 2010))													
616017	TERMINAL	11	295 (S)	TERM	TERM			3	2	7/4.	5.3m	2					REPLACEMENT POLE & STAYS, ADD STUB LEG, NEW 200kVA PMT, LV O/H OFF 2xLV FUSES	FIG 8
633216	LV ANGLE	11	240 (M)	23.79	08°49' RT		LV		1	7/4.	4.3m						REPLACEMENT POLE & STAY	FIG 5
633227	LV INTER	11	240 (M)	27.14			LV										REPLACEMENT POLE REMOVE EXIS STAY	FIG 5
633229	LV ANGLE	9.5	280 (S)	33.96	36°38' LT		LV		1	7/4.	4.6m						EXISTING POLE, REPLACEMENT STAY	
633230	LV ANGLE	10	230 (M)	45.43	03°22' LT		LV		1	7/4.	3.1m						EXISTING POLE REPLACEMENT STAY	
633232	LV ANGLE	11	295 (S)	45.36	19°58' LT		LV		1	7/4.	3.3m						REPLACEMENT POLE & STAY	FIG 5
633233	LV ANGLE	9.5	280 (S)	45.34	02°09' RT		LV		1	7/4.	2.9m						EXISTING POLE, LV U/G REPLACEMENT STAY.	
633234	LV ANGLE	9.5	280 (S)	49.05	08°42' RT		LV		1	7/4.	2.9m						EXISTING POLE REPLACEMENT STAY	
633236	LV TERMINAL	11	295 (S)	50.41	02°49' LT		LV		1	7/4.	3.3m						REPLACEMENT POLE & STAY, LV U/G	FIG 9
633237	LV TERMINAL	9	240	49.85	TERM		LV		2	7/4.	3.3m						EXISTING POLE & STAYS LV U/G	
WAYLEAVE CLASS : (1) ARABLE (2) FENCE ADJACENT ARABLE (3) PASTURE (4) FENCE ADJACENT PASTURE (5) ROUGH (6) FENCE ADJACENT ROUGH																	UK POWER NETWORKS	
ACCOMPANYING PAPERS : PROFILE / 01-240954-01 TREE SCHEDULE / 04-240954-04 ROUTE PLAN / 03-240954-03																		