

Delegated Decision

Sign off Sheet

Ref. No:	DM/26/2393	Case Officer:	Peter Davies
Application Type:	Overhead Electricity Line		
Proposal:	PHASE 1 - To install a new stout pole. To cut the existing Low Voltage (LV) overhead line between pole 629949 and 80 Western Road, and reconnect to the new stout pole as shown on plan UKPN8500369207-1-500-PH1. To install a new temporary LV pole. To cut the existing overhead spur between 80 and 82 Western Road, and reconnect to the new temporary LV pole. To install a new 2w 50ABC cable from the temporary pole to 82 Western Road. PHASE 2 - To remove the existing overhead spur (between no. 80 and the temporary pole) from the pole and connect to the corner of the finished extension at no. 82 Western Road.		
Site:	82 Western Road, Haywards Heath, West Sussex, RH16 3LN, , , ,		
Validation Date	28 Sep 2026	Overall Expiry Date:	
Pre-Commencement Conditions Required:		Pre-Com Conditions Date Agreed:	
Recommendation:	No Objection	Recommendation Date:	7 Oct 2026
Target Date:	9 Nov 2026	Recommending Officer Signature:	Peter Davies

Date Legal Agreement Completed: (if applicable)		No of Representations:	0
--	--	-------------------------------	---

Signed and Agreed By:	Steven King	Date:	7 Oct 2026
Comments:			

MID SUSSEX DISTRICT COUNCIL

DM/26/2393

82 Western Road, Haywards Heath, West Sussex, RH16 3LN, , ,

PHASE 1 - To install a new stout pole. To cut the existing Low Voltage (LV) overhead line between pole 629949 and 80 Western Road, and reconnect to the new stout pole as shown on plan UKPN8500369207-1-500-PH1. To install a new temporary LV pole. To cut the existing overhead spur between 80 and 82 Western Road, and reconnect to the new temporary LV pole. To install a new 2w 50ABC cable from the temporary pole to 82 Western Road.

PHASE 2 - To remove the existing overhead spur (between no. 80 and the temporary pole) from the pole and connect to the corner of the finished extension at no. 82 Western Road.

Stessie Aristide

Decision: No Objection

Case Officer: Peter Davies