



Notes:

Size of Fire hydrant supply:- 90mm
(Existing pipe which serves Fire Hydrant outside main gates of Ote Hall Face located circa 100meters to the north).

Ownership: Privately Owned.

85metres distance from proposed hydrant to front door of fame shop/cafe, taken up the road and main site entrance and round to the main entrance point.

West Sussex Fire and Rescue Service to be informed when the Fire Hydrant H is in place and ready for use, which is t be prior to any occupation or use of the property so we WSFRS can test it, mark it up with H plate, spray the cover yellow and plot the FH on the operational mapping to ensure any attending fire crews know where the FH is located.

Owner to ensure an Fire Hydrant cover is on the FH and not a WO (Wash Out) cover.

CROWTHER
ARCHITECTS
ASSOCIATES

CROWTHER ASSOCIATES ARCHITECTS LLP
LGF, 100/101 Queens Road,
Brighton, BN1 3XF.
T: 01273 695535
www.crowtherassociates.co.uk

client
Ote Hall Farm

project
Ote Hall Farm

drawing
Fire Hydrant Location
Planning Condition 14

date	scale	drawn	checked
Nov 2024	1:250 @ A1	EA	JJ
status			

See Issue Sheet

job no	dwg no	revision
C-2105 (08)02		PA2