

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 28 February 2025 14:17:36 UTC+00:00
To: "Stefan Galyas" <Stefan.Galyas@midsussex.gov.uk>
Subject: DM/25/0049

Hi Stefan,

I recommend the following condition be applied to any permission granted.

Heat Pump: Unless otherwise agreed, the air source heat pump serving the property shall not come into use until a scheme has been submitted to the LPA demonstrating that the noise rating level (L_Ar,Tr) of the heat pump operating at the maximum setting shall be at least 5dB below the background noise level (L_A90,T) at the nearest residential facade. All measurements shall be defined and derived in accordance with BS4142: 2014+A1:2019.

Reason: to protect the amenity of local residents.

Kind regards,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk



"Working together for a better Mid Sussex"