

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>

Sent: 14 July 2026 16:18

To: Caroline Grist <Caroline.Grist@midsussex.gov.uk>

Subject: RE: Planning consultation - DM/25/2833 Hampton House High Street East
Grinstead West Sussex RH19 3AW

Hi Caroline,

Providing the system is compliant with and installed to BS8458 standard the water mist system will be considered suitable and fit for purpose.

Regards

Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West
Sussex, PO19 1BD