

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:17

Project Information			
Assessed By	Joe Mountain	Building Type	Bungalow, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	66 m ²
Site Reference	House Type F	Plot Reference	Plot 1
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	10.88 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	5.52 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	58.15 kWh _{PE} /m ²		
Dwelling primary energy	58.09 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	45.8 kWh/m ²		
Dwelling fabric energy efficiency	41.0 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	63.97	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	66	0.12	
Exposed roof: Roof (1)	66	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	6.3	East	0.7	1.2
Opening, Opening Type 1	9.13	West	0.7	1.2
Opening, Opening Type 1	1	South	0.7	1.2
Opening, Opening Type 1	1.2	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E16: Corner (normal)	Not government-approved scheme	0 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	252.8%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting		
Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:20

Project Information			
Assessed By	Joe Mountain	Building Type	Bungalow, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	66 m ²
Site Reference	House Type F	Plot Reference	Plot 2
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	10.88 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	5.14 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	58.15 kWh _{PE} /m ²		
Dwelling primary energy	53.95 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	45.8 kWh/m ²		
Dwelling fabric energy efficiency	41.0 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	63.97	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	66	0.12	
Exposed roof: Roof (1)	66	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	6.3	East	0.7	1.2
Opening, Opening Type 1	9.13	West	0.7	1.2
Opening, Opening Type 1	1	South	0.7	1.2
Opening, Opening Type 1	1.2	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E16: Corner (normal)	Not government-approved scheme	0 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	252.8%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting		
Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
Technology type: Photovoltaic system (1)		
Peak power	0.3 kWp	
Orientation	South	
Pitch	30°	
Overshading	Modest	
Manufacturer		
MCS certificate		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:20

Project Information			
Assessed By	Joe Mountain	Building Type	Bungalow, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	66 m ²
Site Reference	House Type F	Plot Reference	Plot 3
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	10.88 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	5.14 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	58.15 kWh _{PE} /m ²		
Dwelling primary energy	53.95 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	45.8 kWh/m ²		
Dwelling fabric energy efficiency	41.0 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	63.97	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	66	0.12	
Exposed roof: Roof (1)	66	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	6.3	East	0.7	1.2
Opening, Opening Type 1	9.13	West	0.7	1.2
Opening, Opening Type 1	1	South	0.7	1.2
Opening, Opening Type 1	1.2	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E16: Corner (normal)	Not government-approved scheme	0 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	252.8%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting		
Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
Technology type: Photovoltaic system (1)		
Peak power	0.3 kWp	
Orientation	South	
Pitch	30°	
Overshading	Modest	
Manufacturer		
MCS certificate		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:22

Project Information			
Assessed By	Joe Mountain	Building Type	Flat, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	50 m ²
Site Reference	House Type T	Plot Reference	Plot 4
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	15.89 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	5.62 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	83.76 kWh _{PE} /m ²		
Dwelling primary energy	59.26 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	47.4 kWh/m ²		
Dwelling fabric energy efficiency	39.7 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	N/A	N/A	N/A
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))		
Name	Net area [m ²]	U-Value [W/m ² K]
Exposed wall: Walls (1)	24.4	0.19
Ground floor: Heatloss Floor 1, Heatloss Floor 1	50	0.12

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	5.3	North	0.7	1.2
Opening, Opening Type 1	5.8	East	0.7	1.2
Opening, Opening Type 1	9.5	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²		
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference			

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	253.5%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W		
Lowest light source efficacy	100 lm/W		OK
External lights control	N/A		

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
Technology type: Photovoltaic system (1)		
Peak power	0.1 kWp	
Orientation	South	
Pitch	30°	
Overshading	Modest	
Manufacturer		
MCS certificate		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:22

Project Information			
Assessed By	Joe Mountain	Building Type	Flat, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	51 m ²
Site Reference	House Type T	Plot Reference	Plot 5
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	15.5 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	5.6 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	81.61 kWh _{PE} /m ²		
Dwelling primary energy	59.03 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	45.7 kWh/m ²		
Dwelling fabric energy efficiency	41.8 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	N/A	N/A	N/A
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	24.4	0.19	
Exposed roof: Roof (1)	50	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	5.3	North	0.7	1.2
Opening, Opening Type 1	5.8	East	0.7	1.2
Opening, Opening Type 1	9.5	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²		
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference			

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	253.2%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
Technology type: Photovoltaic system (1)		
Peak power	0.2 kWp	
Orientation	South	
Pitch	30°	
Overshading	Modest	
Manufacturer		
MCS certificate		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:18

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	126 m ²
Site Reference	House Type J	Plot Reference	Plot 6
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.39 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.9 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	49.03 kWh _{PE} /m ²		
Dwelling primary energy	40.93 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	39.5 kWh/m ²		
Dwelling fabric energy efficiency	35.8 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	136.5	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	70	0.12	
Exposed roof: Roof (1)	14	0.15	
Exposed roof: Roof (2)	56	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	11.9	North	0.7	1.2
Opening, Opening Type 1	11.8	South	0.7	1.2
Opening, Opening Type 1	7.1	East	0.7	1.2
Opening, Opening Type 1	4.7	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	294.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting		
Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:25

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	100 m ²
Site Reference	House Type U	Plot Reference	Plot 7
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	13.45 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.65 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	70.6 kWh _{PE} /m ²		
Dwelling primary energy	48.69 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	48.5 kWh/m ²		
Dwelling fabric energy efficiency	41.9 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))		
Name	Net area [m ²]	U-Value [W/m ² K]
Exposed wall: Walls (1)	158.3	0.19
Ground floor: Heatloss Floor 1, Heatloss Floor 1	76	0.12
Exposed roof: Roof (1)	23	0.15
Exposed roof: Roof (2)	2	0.15

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	8.3	West	0.7	1.2
Opening, Opening Type 1	6.2	North	0.7	1.2
Opening, Opening Type 1	9.2	East	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	277.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
Technology type: Photovoltaic system (1)		
Peak power	0.4 kWp	
Orientation	South	
Pitch	30°	
Overshading	Modest	
Manufacturer		
MCS certificate		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:25

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	130 m ²
Site Reference	House Type U	Plot Reference	Plot 8
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	10.37 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.8 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	54.17 kWh _{PE} /m ²		
Dwelling primary energy	39.93 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	38.7 kWh/m ²		
Dwelling fabric energy efficiency	33.5 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	151	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	46	0.12	
Exposed roof: Roof (1)	46	0.15	
Exposed roof: Roof (2)	2	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	11.5	South	0.7	1.2
Opening, Opening Type 1	8	North	0.7	1.2
Opening, Opening Type 1	11.5	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	291.9%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:18

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	145 m ²
Site Reference	House Type L	Plot Reference	Plot 9
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.2 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.62 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	48.18 kWh _{PE} /m ²		
Dwelling primary energy	37.84 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	41.1 kWh/m ²		
Dwelling fabric energy efficiency	37.1 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	149.7	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	80	0.12	
Exposed roof: Roof (1)	65	0.15	
Exposed roof: Roof (2)	16	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	14	West	0.7	1.2
Opening, Opening Type 1	12.4	South	0.7	1.2
Opening, Opening Type 1	11.75	North	0.7	1.2
Opening, Opening Type 1	4.15	East	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	306.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting		
Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:24

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	137 m ²
Site Reference	House Type M	Plot Reference	Plot 10
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.64 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.77 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	50.39 kWh _{PE} /m ²		
Dwelling primary energy	39.43 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	41.7 kWh/m ²		
Dwelling fabric energy efficiency	38.3 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))		
Name	Net area [m ²]	U-Value [W/m ² K]
Exposed wall: Walls (1)	139.94	0.19
Ground floor: Heatloss Floor 1, Heatloss Floor 1	72	0.12
Exposed roof: Roof (1)	65	0.15
Exposed roof: Roof (2)	7	0.15

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	15.8	West	0.7	1.2
Opening, Opening Type 1	16.9	East	0.7	1.2
Opening, Opening Type 1	1.76	South	0.7	1.2
Opening, Opening Type 1	5.6	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	301.0%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:24

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	184 m ²
Site Reference	House Type P	Plot Reference	Plot 11
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.63 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.43 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	50.5 kWh _{PE} /m ²		
Dwelling primary energy	35.7 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	43.2 kWh/m ²		
Dwelling fabric energy efficiency	39.9 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))		
Name	Net area [m ²]	U-Value [W/m ² K]
Exposed wall: Walls (1)	217.67	0.19
Ground floor: Heatloss Floor 1, Heatloss Floor 1	80	0.12
Exposed roof: Roof (1)	64	0.15
Exposed roof: Roof (2)	16	0.15

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	19.07	West	0.7	1.2
Opening, Opening Type 1	4.75	East	0.7	1.2
Opening, Opening Type 1	21.86	North	0.7	1.2
Opening, Opening Type 1	10.65	South	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	317.7%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:19

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	228 m ²
Site Reference	House Type R	Plot Reference	Plot 12
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	7.25 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	2.75 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	37.74 kWh _{PE} /m ²		
Dwelling primary energy	28.7 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	33.5 kWh/m ²		
Dwelling fabric energy efficiency	30.3 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	124.6	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	72	0.12	
Exposed roof: Roof (1)	72	0.15	
Exposed roof: Roof (2)	12	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	16.5	South	0.7	1.2
Opening, Opening Type 1	23.4	North	0.7	1.2
Opening, Opening Type 1	8.5	East	0.7	1.2
Opening, Opening Type 1	4	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	317.5%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:25

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	228 m ²
Site Reference	House Type R	Plot Reference	Plot 13
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	7.25 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	2.75 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	37.74 kWh _{PE} /m ²		
Dwelling primary energy	28.7 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	33.5 kWh/m ²		
Dwelling fabric energy efficiency	30.3 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	124.6	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	72	0.12	
Exposed roof: Roof (1)	72	0.15	
Exposed roof: Roof (2)	12	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	16.5	South	0.7	1.2
Opening, Opening Type 1	23.4	North	0.7	1.2
Opening, Opening Type 1	8.5	East	0.7	1.2
Opening, Opening Type 1	4	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	317.5%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:19

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	184 m ²
Site Reference	House Type P	Plot Reference	Plot 14
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	8.98 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.24 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	47.01 kWh _{PE} /m ²		
Dwelling primary energy	33.76 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	40.4 kWh/m ²		
Dwelling fabric energy efficiency	36.5 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	217.67	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	80	0.12	
Exposed roof: Roof (1)	64	0.15	
Exposed roof: Roof (2)	16	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	19.07	East	0.7	1.2
Opening, Opening Type 1	4.75	West	0.7	1.2
Opening, Opening Type 1	21.86	South	0.7	1.2
Opening, Opening Type 1	10.65	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	317.7%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:18

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	137 m ²
Site Reference	House Type M	Plot Reference	Plot 15
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.35 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.69 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	48.84 kWh _{PE} /m ²		
Dwelling primary energy	38.58 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	40.4 kWh/m ²		
Dwelling fabric energy efficiency	36.8 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	139.94	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	72	0.12	
Exposed roof: Roof (1)	65	0.15	
Exposed roof: Roof (2)	7	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	15.8	East	0.7	1.2
Opening, Opening Type 1	16.9	West	0.7	1.2
Opening, Opening Type 1	1.76	North	0.7	1.2
Opening, Opening Type 1	5.6	South	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	301.0%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:23

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	137 m ²
Site Reference	House Type M	Plot Reference	Plot 16
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.35 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.69 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	48.84 kWh _{PE} /m ²		
Dwelling primary energy	38.58 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	40.4 kWh/m ²		
Dwelling fabric energy efficiency	36.8 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	139.94	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	72	0.12	
Exposed roof: Roof (1)	65	0.15	
Exposed roof: Roof (2)	7	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	15.8	East	0.7	1.2
Opening, Opening Type 1	16.9	West	0.7	1.2
Opening, Opening Type 1	1.76	North	0.7	1.2
Opening, Opening Type 1	5.6	South	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	301.0%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:		
	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:24

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	145 m ²
Site Reference	House Type L	Plot Reference	Plot 17
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.2 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.62 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	48.18 kWh _{PE} /m ²		
Dwelling primary energy	37.84 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	41.1 kWh/m ²		
Dwelling fabric energy efficiency	37.1 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	149.7	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	80	0.12	
Exposed roof: Roof (1)	65	0.15	
Exposed roof: Roof (2)	16	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	14	East	0.7	1.2
Opening, Opening Type 1	12.4	South	0.7	1.2
Opening, Opening Type 1	11.75	North	0.7	1.2
Opening, Opening Type 1	4.15	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	306.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting		
Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:22

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	126 m ²
Site Reference	House Type J	Plot Reference	Plot 18
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.39 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.9 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	49.03 kWh _{PE} /m ²		
Dwelling primary energy	40.93 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	39.5 kWh/m ²		
Dwelling fabric energy efficiency	35.8 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	136.5	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	70	0.12	
Exposed roof: Roof (1)	14	0.15	
Exposed roof: Roof (2)	56	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	11.9	North	0.7	1.2
Opening, Opening Type 1	11.8	South	0.7	1.2
Opening, Opening Type 1	7.1	East	0.7	1.2
Opening, Opening Type 1	4.7	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	294.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting	
Minimum permitted light source efficacy	75 lm/W
Lowest light source efficacy	100 lm/W
External lights control	N/A

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:22

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	126 m ²
Site Reference	House Type J	Plot Reference	Plot 19
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.39 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.9 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	49.03 kWh _{PE} /m ²		
Dwelling primary energy	40.93 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	39.5 kWh/m ²		
Dwelling fabric energy efficiency	35.8 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	136.5	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	70	0.12	
Exposed roof: Roof (1)	14	0.15	
Exposed roof: Roof (2)	56	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	11.9	North	0.7	1.2
Opening, Opening Type 1	11.8	South	0.7	1.2
Opening, Opening Type 1	7.1	East	0.7	1.2
Opening, Opening Type 1	4.7	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	294.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting		
Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:22

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	130 m ²
Site Reference	House Type U	Plot Reference	Plot 20
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	11.17 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.02 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	58.48 kWh _{PE} /m ²		
Dwelling primary energy	42.13 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	42.3 kWh/m ²		
Dwelling fabric energy efficiency	37.6 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	151	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	46	0.12	
Exposed roof: Roof (1)	46	0.15	
Exposed roof: Roof (2)	2	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	11.5	West	0.7	1.2
Opening, Opening Type 1	8	East	0.7	1.2
Opening, Opening Type 1	11.5	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	291.9%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:23

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	100 m ²
Site Reference	House Type U	Plot Reference	Plot 21
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	12.62 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.43 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	66.09 kWh _{PE} /m ²		
Dwelling primary energy	46.37 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	44.9 kWh/m ²		
Dwelling fabric energy efficiency	38.0 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	158.3	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	76	0.12	
Exposed roof: Roof (1)	23	0.15	
Exposed roof: Roof (2)	2	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	8.3	East	0.7	1.2
Opening, Opening Type 1	6.2	South	0.7	1.2
Opening, Opening Type 1	9.2	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	277.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
Technology type: Photovoltaic system (1)		
Peak power	0.4 kWp	
Orientation	South	
Pitch	30°	
Overshading	Modest	
Manufacturer		
MCS certificate		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:18

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	130 m ²
Site Reference	House Type I	Plot Reference	Plot 22
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	8.86 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.82 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	46.0 kWh _{PE} /m ²		
Dwelling primary energy	40.28 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	33.4 kWh/m ²		
Dwelling fabric energy efficiency	31.7 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	58.3	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	50	0.12	
Exposed roof: Roof (1)	50	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	19.1	West	0.7	1.2
Opening, Opening Type 1	13.7	East	0.7	1.2
Opening, Opening Type 1	4.9	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	284.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting	
Minimum permitted light source efficacy	75 lm/W
Lowest light source efficacy	100 lm/W
External lights control	N/A

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:21

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	130 m ²
Site Reference	House Type I	Plot Reference	Plot 23
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	8.58 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.74 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	44.5 kWh _{PE} /m ²		
Dwelling primary energy	39.42 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	32.2 kWh/m ²		
Dwelling fabric energy efficiency	30.3 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	58.3	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	50	0.12	
Exposed roof: Roof (1)	50	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	19.1	West	0.7	1.2
Opening, Opening Type 1	13.7	East	0.7	1.2
Opening, Opening Type 1	4.9	South	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	284.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting	
Minimum permitted light source efficacy	75 lm/W
Lowest light source efficacy	100 lm/W
External lights control	N/A

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:25

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	451 m ²
Site Reference	House Type G	Plot Reference	Plot 24
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	5.02 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	1.86 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	26.72 kWh _{PE} /m ²		
Dwelling primary energy	19.35 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	19.8 kWh/m ²		
Dwelling fabric energy efficiency	18.8 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	65.4	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	41	0.12	
Exposed roof: Roof (1)	41	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	5.3	South	0.7	1.2
Opening, Opening Type 1	5.8	East	0.7	1.2
Opening, Opening Type 1	9.5	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	318.8%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:25

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	99 m ²
Site Reference	House Type G	Plot Reference	Plot 25
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.51 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.41 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	49.35 kWh _{PE} /m ²		
Dwelling primary energy	46.41 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	34.1 kWh/m ²		
Dwelling fabric energy efficiency	33.9 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))		
Name	Net area [m ²]	U-Value [W/m ² K]
Exposed wall: Walls (1)	53.4	0.19
Ground floor: Heatloss Floor 1, Heatloss Floor 1	51	0.12
Exposed roof: Roof (1)	48	0.15

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	12.2	North	0.7	1.2
Opening, Opening Type 1	1.8	South	0.7	1.2
Opening, Opening Type 1	9.3	East	0.7	1.2
Opening, Opening Type 1	9.7	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²		
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference			

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	261.2%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W		
Lowest light source efficacy	100 lm/W		OK
External lights control	N/A		

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:17

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	100 m ²
Site Reference	House Type E	Plot Reference	Plot 26
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	8.97 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.07 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	46.63 kWh _{PE} /m ²		
Dwelling primary energy	42.93 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	29.8 kWh/m ²		
Dwelling fabric energy efficiency	26.4 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	89.4	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	50	0.12	
Exposed roof: Roof (1)	50	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	5.9	South	0.7	1.2
Opening, Opening Type 1	4.7	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.042	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	253.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:20

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	100 m ²
Site Reference	House Type E	Plot Reference	Plot 27
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	8.97 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.07 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	46.63 kWh _{PE} /m ²		
Dwelling primary energy	42.93 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	29.8 kWh/m ²		
Dwelling fabric energy efficiency	26.4 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	89.4	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	50	0.12	
Exposed roof: Roof (1)	50	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	5.9	South	0.7	1.2
Opening, Opening Type 1	4.7	East	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.042	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	253.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:16

Project Information			
Assessed By	Joe Mountain	Building Type	Flat, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	56 m ²
Site Reference	House Type A	Plot Reference	Plot 28
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	14.44 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	5.26 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	76.3 kWh _{PE} /m ²		
Dwelling primary energy	55.64 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	38.1 kWh/m ²		
Dwelling fabric energy efficiency	32.4 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	N/A	N/A	N/A
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))		
Name	Net area [m ²]	U-Value [W/m ² K]
Exposed wall: Walls (1)	47.9	0.19
Ground floor: Heatloss Floor 1, Heatloss Floor 1	56	0.12

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	5.65	South	0.7	1.2
Opening, Opening Type 1	4.65	North	0.7	1.2
Opening, Opening Type 1	3.8	West	0.7	1.2
Opening, Opening Type 2	3	West	N/A	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E7: Party floor between dwellings (in blocks of flats)	Not government-approved scheme	0.051	
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	253.5%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation

System type: N/A

Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		

9 Local generation	
N/A	
10 Heat networks	
N/A	
11 Supporting documentary evidence	
N/A	
12 Declarations	
a. Assessor Declaration	
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.	
Signed: Name:	Assessor ID: Date:
b. Client Declaration	
N/A	

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:16

Project Information			
Assessed By	Joe Mountain	Building Type	Flat, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	51 m ²
Site Reference	House Type A	Plot Reference	Plot29
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	14.89 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	5.29 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	78.82 kWh _{PE} /m ²		
Dwelling primary energy	56.13 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	38.1 kWh/m ²		
Dwelling fabric energy efficiency	30.8 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	N/A	N/A	N/A
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	53.66	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	51	0.12	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	4.54	South	0.7	1.2
Opening, Opening Type 1	4.8	North	0.7	1.2
Opening, Opening Type 1	2	East	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E7: Party floor between dwellings (in blocks of flats)	Not government-approved scheme	0.051	
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	256.0%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation

System type: N/A

Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		

9 Local generation	
N/A	
10 Heat networks	
N/A	
11 Supporting documentary evidence	
N/A	
12 Declarations	
a. Assessor Declaration	
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.	
Signed: Name:	Assessor ID: Date:
b. Client Declaration	
N/A	

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:16

Project Information			
Assessed By	Joe Mountain	Building Type	Flat, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	57 m ²
Site Reference	House Type A	Plot Reference	Plot 30
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	11.83 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.61 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	62.25 kWh _{PE} /m ²		
Dwelling primary energy	49.03 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	26.8 kWh/m ²		
Dwelling fabric energy efficiency	23.1 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	N/A	N/A	N/A
Roofs	0.16	N/A	N/A	N/A
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))		
Name	Net area [m ²]	U-Value [W/m ² K]
Exposed wall: Walls (1)	46.3	0.19

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	4.8	South	0.7	1.2
Opening, Opening Type 1	5.7	West	0.7	1.2
Opening, Opening Type 1	3.2	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E7: Party floor between dwellings (in blocks of flats)	Not government-approved scheme	0.051	
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	257.2%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation

System type: N/A

Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		

9 Local generation

N/A

10 Heat networks	
N/A	
11 Supporting documentary evidence	
N/A	
12 Declarations	
a. Assessor Declaration	
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.	
Signed: Name:	Assessor ID: Date:
b. Client Declaration	
N/A	

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:16

Project Information			
Assessed By	Joe Mountain	Building Type	Flat, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	57 m ²
Site Reference	House Type A	Plot Reference	Plot 31
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	11.5 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.51 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	60.5 kWh _{PE} /m ²		
Dwelling primary energy	48.09 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	24.5 kWh/m ²		
Dwelling fabric energy efficiency	20.7 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	N/A	N/A	N/A
Roofs	0.16	N/A	N/A	N/A
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))		
Name	Net area [m ²]	U-Value [W/m ² K]
Exposed wall: Walls (1)	49.6	0.19

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	5.4	South	0.7	1.2
Opening, Opening Type 1	2	East	0.7	1.2
Opening, Opening Type 1	3	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E7: Party floor between dwellings (in blocks of flats)	Not government-approved scheme	0.051	
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	258.5%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation

System type: N/A

Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		

9 Local generation

N/A

10 Heat networks	
N/A	
11 Supporting documentary evidence	
N/A	
12 Declarations	
a. Assessor Declaration	
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.	
Signed: Name:	Assessor ID: Date:
b. Client Declaration	
N/A	

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:16

Project Information			
Assessed By	Joe Mountain	Building Type	Flat, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	101 m ²
Site Reference	House Type A	Plot Reference	Plot 32
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.84 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.14 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	51.61 kWh _{PE} /m ²		
Dwelling primary energy	43.73 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	28.7 kWh/m ²		
Dwelling fabric energy efficiency	28.0 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	N/A	N/A	N/A
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	92.4	0.19	
Exposed roof: Roof (1)	101	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	3	South	0.7	1.2
Opening, Opening Type 1	3	North	0.7	1.2
Opening, Opening Type 1	1.6	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	253.1%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation

System type: N/A

Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		

9 Local generation

N/A	
10 Heat networks	
N/A	
11 Supporting documentary evidence	
N/A	
12 Declarations	
a. Assessor Declaration	
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.	
Signed: Name:	Assessor ID: Date:
b. Client Declaration	
N/A	

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:17

Project Information			
Assessed By	Joe Mountain	Building Type	Flat, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	61 m ²
Site Reference	House Type B	Plot Reference	Plot 33
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	13.49 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	5.22 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	70.74 kWh _{PE} /m ²		
Dwelling primary energy	55.09 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	41.3 kWh/m ²		
Dwelling fabric energy efficiency	34.5 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	N/A	N/A	N/A
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))		
Name	Net area [m ²]	U-Value [W/m ² K]
Exposed wall: Walls (1)	60.23	0.19
Ground floor: Heatloss Floor 1, Heatloss Floor 1	61	0.12

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	5	East	0.7	1.2
Opening, Opening Type 1	4.41	West	0.7	1.2
Opening, Opening Type 1	5.36	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E7: Party floor between dwellings (in blocks of flats)	Not government-approved scheme	0.051	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	253.1%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation

System type: N/A

Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		

9 Local generation

N/A	
10 Heat networks	
N/A	
11 Supporting documentary evidence	
N/A	
12 Declarations	
a. Assessor Declaration	
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.	
Signed: Name:	Assessor ID: Date:
b. Client Declaration	
N/A	

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:19

Project Information			
Assessed By	Joe Mountain	Building Type	Flat, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	61 m ²
Site Reference	House Type B	Plot Reference	Plot 34
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	12.13 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	5.16 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	63.41 kWh _{PE} /m ²		
Dwelling primary energy	54.53 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	34.8 kWh/m ²		
Dwelling fabric energy efficiency	33.1 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	N/A	N/A	N/A
Roofs	0.16	0.16	Roof (1) (0.16)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))		
Name	Net area [m ²]	U-Value [W/m ² K]
Exposed wall: Walls (1)	61.04	0.19
Exposed roof: Roof (1)	61	0.16

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	6.16	East	0.7	1.2
Opening, Opening Type 1	3.3	West	0.7	1.2
Opening, Opening Type 1	2.45	North	0.7	1.2
Opening, Opening Type 1	2.05	South	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E7: Party floor between dwellings (in blocks of flats)	Not government-approved scheme	0.051	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	253.1%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation

System type: N/A

Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		

9 Local generation

N/A	
10 Heat networks	
N/A	
11 Supporting documentary evidence	
N/A	
12 Declarations	
a. Assessor Declaration	
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.	
Signed: Name:	Assessor ID: Date:
b. Client Declaration	
N/A	

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:17

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	102 m ²
Site Reference	House Type D	Plot Reference	Plot 35
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.23 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.05 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	47.87 kWh _{PE} /m ²		
Dwelling primary energy	42.75 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	32.3 kWh/m ²		
Dwelling fabric energy efficiency	28.6 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	65.85	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	51	0.12	
Exposed roof: Roof (1)	51	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	7.7	North	0.7	1.2
Opening, Opening Type 1	7.85	South	0.7	1.2
Opening, Opening Type 1	5	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	254.0%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:20

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	102 m ²
Site Reference	House Type D	Plot Reference	Plot 36
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.23 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.05 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	47.87 kWh _{PE} /m ²		
Dwelling primary energy	42.75 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	32.3 kWh/m ²		
Dwelling fabric energy efficiency	28.6 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	65.85	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	51	0.12	
Exposed roof: Roof (1)	51	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	7.7	North	0.7	1.2
Opening, Opening Type 1	7.85	South	0.7	1.2
Opening, Opening Type 1	5	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	254.0%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:25

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	76 m ²
Site Reference	House Type D	Plot Reference	Plot 37
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	10.39 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.51 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	54.11 kWh _{PE} /m ²		
Dwelling primary energy	47.7 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	30.8 kWh/m ²		
Dwelling fabric energy efficiency	27.5 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	74.95	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	38	0.12	
Exposed roof: Roof (1)	38	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	4.8	North	0.7	1.2
Opening, Opening Type 1	5.85	South	0.7	1.2
Opening, Opening Type 1	0.8	East	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	252.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:20

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	76 m ²
Site Reference	House Type D	Plot Reference	Plot 38
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	10.39 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.51 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	54.11 kWh _{PE} /m ²		
Dwelling primary energy	47.7 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	30.8 kWh/m ²		
Dwelling fabric energy efficiency	27.5 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	74.95	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	38	0.12	
Exposed roof: Roof (1)	38	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	4.8	North	0.7	1.2
Opening, Opening Type 1	5.85	South	0.7	1.2
Opening, Opening Type 1	0.8	East	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	252.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:21

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	99 m ²
Site Reference	House Type G	Plot Reference	Plot 39
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.51 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.41 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	49.35 kWh _{PE} /m ²		
Dwelling primary energy	46.41 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	34.1 kWh/m ²		
Dwelling fabric energy efficiency	33.9 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	53.4	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	51	0.12	
Exposed roof: Roof (1)	48	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	12.2	North	0.7	1.2
Opening, Opening Type 1	1.8	South	0.7	1.2
Opening, Opening Type 1	9.3	East	0.7	1.2
Opening, Opening Type 1	9.7	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²		
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference			

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	261.2%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W		
Lowest light source efficacy	100 lm/W		OK
External lights control	N/A		

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:21

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	451 m ²
Site Reference	House Type G	Plot Reference	Plot 40
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	5.02 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	1.86 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	26.72 kWh _{PE} /m ²		
Dwelling primary energy	19.35 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	19.8 kWh/m ²		
Dwelling fabric energy efficiency	18.8 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	65.4	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	41	0.12	
Exposed roof: Roof (1)	41	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	5.3	South	0.7	1.2
Opening, Opening Type 1	5.8	East	0.7	1.2
Opening, Opening Type 1	9.5	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	318.8%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:21

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	130 m ²
Site Reference	House Type I	Plot Reference	Plot 41
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	8.86 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.82 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	46.0 kWh _{PE} /m ²		
Dwelling primary energy	40.28 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	33.4 kWh/m ²		
Dwelling fabric energy efficiency	31.7 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	58.3	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	50	0.12	
Exposed roof: Roof (1)	50	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	19.1	West	0.7	1.2
Opening, Opening Type 1	13.7	East	0.7	1.2
Opening, Opening Type 1	4.9	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	284.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting		
Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:21

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	130 m ²
Site Reference	House Type I	Plot Reference	Plot 42
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	8.58 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.74 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	44.5 kWh _{PE} /m ²		
Dwelling primary energy	39.42 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	32.2 kWh/m ²		
Dwelling fabric energy efficiency	30.3 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	58.3	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	50	0.12	
Exposed roof: Roof (1)	50	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	19.1	West	0.7	1.2
Opening, Opening Type 1	13.7	East	0.7	1.2
Opening, Opening Type 1	4.9	South	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))				
Maximum permitted air permeability at 50Pa		8 m ³ /hm ²		
Dwelling air permeability at 50Pa		4 m ³ /hm ² , Design value		OK
Air permeability test certificate reference				

4 Space heating	
Main heating system 1: Heat pump with radiators or underfloor heating - Electricity	
Efficiency	284.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	
Secondary heating system: N/A	
Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water	
Cylinder/store - type: Cylinder	
Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	
Waste water heat recovery system 1 - type: N/A	
Efficiency	
Manufacturer	
Model	

6 Controls	
Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services	
Function	
Ecodesign class	
Manufacturer	
Model	
Water heating - type: Cylinder thermostat and HW separately timed	
Manufacturer	
Model	

7 Lighting	
Minimum permitted light source efficacy	75 lm/W
Lowest light source efficacy	100 lm/W
External lights control	N/A

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:19

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	176 m ²
Site Reference	House Type Q	Plot Reference	Plot 43
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	9.33 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.29 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	48.81 kWh _{PE} /m ²		
Dwelling primary energy	34.31 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	40.5 kWh/m ²		
Dwelling fabric energy efficiency	36.1 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	228.2	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	72	0.12	
Exposed roof: Roof (1)	64	0.15	
Exposed roof: Roof (2)	8	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	18.9	South	0.7	1.2
Opening, Opening Type 1	9.6	North	0.7	1.2
Opening, Opening Type 1	12.8	East	0.7	1.2
Opening, Opening Type 1	4.5	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	316.9%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:18

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	182 m ²
Site Reference	House Type K	Plot Reference	Plot 44
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	7.69 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	0.76 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	39.93 kWh _{PE} /m ²		
Dwelling primary energy	16.59 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	32.1 kWh/m ²		
Dwelling fabric energy efficiency	26.2 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	108.6	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	65	0.12	
Exposed roof: Roof (1)	46	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	17.25	North	1.0	1.2
Opening, Opening Type 1	26.75	South	1.0	1.2
Opening, Opening Type 1	5.25	West	1.0	1.2
Opening, Opening Type 1	5.15	East	1.0	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	295.6%
Emitter type	Radiators
Flow temperature	55°C
System type	Heat Pump
Manufacturer	Kensa Heat Pumps Ltd
Model	Evo K090-S1H-0K
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: N/A

Capacity	250 litres
Declared heat loss	1.61 kWh/day
Primary pipework insulated	N/A
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: Instantaneous

Efficiency	59.9%
Manufacturer	ZYPHO SA
Model	PiPe 75

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
Technology type: Photovoltaic system (1)		
Peak power	5 kWp	
Orientation	West	
Pitch	30°	
Overshading	None or very little	
Manufacturer		
MCS certificate		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:25

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	228 m ²
Site Reference	House Type R	Plot Reference	Plot 45
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	7.25 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	2.75 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	37.74 kWh _{PE} /m ²		
Dwelling primary energy	28.7 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	33.5 kWh/m ²		
Dwelling fabric energy efficiency	30.3 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	124.6	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	72	0.12	
Exposed roof: Roof (1)	72	0.15	
Exposed roof: Roof (2)	12	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	16.5	South	0.7	1.2
Opening, Opening Type 1	23.4	North	0.7	1.2
Opening, Opening Type 1	8.5	East	0.7	1.2
Opening, Opening Type 1	4	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	317.5%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:		
	Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:25

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	228 m ²
Site Reference	House Type R	Plot Reference	Plot 46
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	7.25 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	2.75 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	37.74 kWh _{PE} /m ²		
Dwelling primary energy	28.7 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	33.5 kWh/m ²		
Dwelling fabric energy efficiency	30.3 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	124.6	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	72	0.12	
Exposed roof: Roof (1)	72	0.15	
Exposed roof: Roof (2)	12	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	16.5	South	0.7	1.2
Opening, Opening Type 1	23.4	North	0.7	1.2
Opening, Opening Type 1	8.5	East	0.7	1.2
Opening, Opening Type 1	4	West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	317.5%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:23

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	182 m ²
Site Reference	House Type K	Plot Reference	Plot 47
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	7.58 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	2.87 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	39.37 kWh _{PE} /m ²		
Dwelling primary energy	30.02 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	32.1 kWh/m ²		
Dwelling fabric energy efficiency	29.1 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	108.6	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	65	0.12	
Exposed roof: Roof (1)	46	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	17.25	North	0.7	1.2
Opening, Opening Type 1	26.75	South	0.7	1.2
Opening, Opening Type 1	5.25	West	0.7	1.2
Opening, Opening Type 1	5.15	East	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	312.7%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:24

Project Information			
Assessed By	Joe Mountain	Building Type	House, Detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	184 m ²
Site Reference	House Type P	Plot Reference	Plot 48
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	8.98 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.24 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	47.01 kWh _{PE} /m ²		
Dwelling primary energy	33.76 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	40.4 kWh/m ²		
Dwelling fabric energy efficiency	36.5 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	217.67	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	80	0.12	
Exposed roof: Roof (1)	64	0.15	
Exposed roof: Roof (2)	16	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	19.07	East	0.7	1.2
Opening, Opening Type 1	4.75	West	0.7	1.2
Opening, Opening Type 1	21.86	South	0.7	1.2
Opening, Opening Type 1	10.65	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E10: Eaves (insulation at ceiling level)	Not government-approved scheme	0.046	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	317.7%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:17

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	80 m ²
Site Reference	House Type C	Plot Reference	Plot 49
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	10.44 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.46 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	54.33 kWh _{PE} /m ²		
Dwelling primary energy	47.14 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	32.7 kWh/m ²		
Dwelling fabric energy efficiency	28.7 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	71.67	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	40	0.12	
Exposed roof: Roof (1)	40	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	6.98	West	0.7	1.2
Opening, Opening Type 1	3.8	East	0.7	1.2
Opening, Opening Type 1	3.95	South	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	252.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Tue 18 Jun 2024 12:11:19

Project Information			
Assessed By	Joe Mountain	Building Type	House, Semi-detached
OCDEA Registration	EES/027298	Assessment Date	2024-06-18

Dwelling Details			
Assessment Type	As designed	Total Floor Area	80 m ²
Site Reference	House Type C	Plot Reference	Plot 50
Address			

Client Details	
Name	Array
Company	Sigma Homes
Address	

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	10.97 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	4.62 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	57.18 kWh _{PE} /m ²		
Dwelling primary energy	48.76 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	35.2 kWh/m ²		
Dwelling fabric energy efficiency	31.4 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	N/A	N/A	N/A
Curtain walls	1.6	N/A	N/A	N/A
Floors	0.18	0.12	Heatloss Floor 1 (0.12)	OK
Roofs	0.16	0.15	Roof (1) (0.15)	OK
Windows, doors, and roof windows	1.6	1.2	Opening (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	71.67	0.19	
Ground floor: Heatloss Floor 1, Heatloss Floor 1	40	0.12	
Exposed roof: Roof (1)	40	0.15	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
Opening, Opening Type 1	6.98	West	0.7	1.2
Opening, Opening Type 1	3.8	East	0.7	1.2
Opening, Opening Type 1	3.95	North	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1 - Main Dwelling: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E5: Ground floor (normal)	Not government-approved scheme	0.067	
External wall	E6: Intermediate floor within a dwelling	Not government-approved scheme	0.002 (!)	
External wall	E16: Corner (normal)	Not government-approved scheme	0.041	

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E18: Party wall between dwellings	Not government-approved scheme	0.04	
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.024 (!)	
External wall	E3: Sill	Not government-approved scheme	0.019 (!)	
External wall	E4: Jamb	Not government-approved scheme	0.014 (!)	
External wall	E11: Eaves (insulation at rafter level)	Not government-approved scheme	0.011 (!)	
External wall	E12: Gable (insulation at ceiling level)	Not government-approved scheme	0.033 (!)	

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	4 m ³ /hm ² , Design value	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	252.4%
Emitter type	Radiators
Flow temperature	35°C
System type	Heat Pump
Manufacturer	Vaillant Group UK Ltd
Model	aroTHERM 3.5kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.8 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	100 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: N/A		
Maximum permitted specific fan power	N/A	
Specific fan power	N/A	N/A
Minimum permitted heat recovery efficiency	N/A	
Heat recovery efficiency	N/A	N/A
Manufacturer/Model		
Commissioning		
9 Local generation		
N/A		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed: Name:	Assessor ID: Date:	
b. Client Declaration		
N/A		