

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 15 January 2025 13:47:36 UTC+00:00
To: "Caroline Grist" <Caroline.Grist@midsussex.gov.uk>
Subject: DM/24/3034 White Lodge, Ockley Lane, Hassocks

Dear Caroline,

I have reviewed the Arboricultural Implications Assessment and Method Statement and have a query.

During the demolition of the garage and southern entrance, will the category B oak and other trees be protected with fencing? The method Statement states that Arboricultural Supervision is required but being as these works will take place within the RPA's of this category B tree, I need to be assured that it, and adjacent trees will be adequately protected. Please could you request a Tree Protection Plan for the demolition stage of the construction?

A minor point, presumably the holly marked as T2 is supposed to be T20. Could you ask for confirmation, please?

Once these points have been addressed, please reconsult me.

Kind regards

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex