

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 25 July 2025 09:10:37 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: FW: Planning consultation - DM/25/0345 Holmsted Farm Staplefield Road
Cuckfield Haywards Heath West Sussex RH17 5JF

FAO: Andrew Watt

Dear Andrew,

Having viewed the plans for the planning application no. DM/25/0345 for the erection of a mixed use commercial building for a flexible commercial use of Class E(g) ((i) Offices to carry out any operational of administrative functions, (ii) Research and development of products or processes and (iii) Industrial processes) and B8 Storage or distribution; the nearest fire hydrant for the supply of water for firefighting is 360 metres away, 270-metres further than the 90-metre distance required for a commercial premises. If an alternative water supply for firefighting is to be considered it will need to conform with the details identified in Approved Document-B (AD-B) Volume 2: B5 section 16 and agreed with West Sussex Fire & Rescue Service.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his 🏳️‍🌈

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
