

Rachel Richardson
Development Control
Mid Sussex District Council
Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Lead Local Flood Authority

Date 02 March 2026

Dear Rachel,

RE: DM/24/2874 – Twineham Court Farm, Bob Lane, Haywards Heath, RH17 5NH

Thank you for your consultation on the above site. We have reviewed the application as submitted and wish to make the following comments.

Proposed removal of the modern disused and redundant agricultural buildings and creation of an events venue through the erection of an events barn and open barn. Proposed use of redundant Grade II Listed farmhouse and Curtilage Listed Building to provide ancillary accommodation to serve the events venue. Proposed erection of estate barn to assist with operation of events venue and retained agricultural land. Creation of new vehicular access onto Bob Lane and provision of driveway and parking area, plus ancillary infrastructure including surface and foul water drainage strategy. Provision of ecological enhancements and hard and soft landscaping.

This is a full application therefore the level of detail submitted raised concerns that there was several issues with the Drainage Strategy which could increase flood risk elsewhere.

The clarification provided addresses the LLFA's previous concerns and therefore, we have **no objection subject to conditions** being attached to any consent if this application is approved, and the Applicant is in agreement with pre-commencement conditions. We suggest the following wording. If the following conditions are not included, the development would be contrary to NPPF and local planning policy Mid Sussex District Council and we would object until such time that the details below are submitted for review.

Condition 1:

Prior to the commencement of development, construction drawings of the surface water drainage network, associated sustainable drainage components and flow control mechanisms and a construction method statement shall be submitted and agreed in writing by the local planning authority. The scheme shall then be constructed as per the agreed drawings, method statement, FRA & Drainage Strategy as listed at the start of this

letter and remaining in perpetuity for the lifetime of the development unless agreed in writing by the Local Planning Authority. No alteration to the agreed drainage scheme shall occur without prior written approval from the Local Authority.

Reason: To ensure that the development achieves a high standard of sustainability and to comply with NPPF Policies of Mid Sussex Council.

Condition 2:

The development hereby approved shall not be occupied until details of the maintenance and management of the sustainable drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The drainage scheme shall be implemented prior to the first occupation of the development hereby approved and thereafter managed and maintained in accordance with the approved details in perpetuity. The Local Planning Authority shall be granted access to inspect the sustainable drainage scheme for the lifetime of the development. The details of the scheme to be submitted for approval shall include:

- I. a timetable for its implementation.
- II. details of SuDS feature and connecting drainage structures and maintenance requirement for each aspect including a drawing showing where they are located.
- III. a management and maintenance plan for the lifetime of the development which shall include the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime. This will include the name and contact details of any appointed management company.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Policies of Mid Sussex Council.

Condition 3:

Upon completion of the surface water drainage system, including any SuDS features, and prior to the first use of the development; a survey and verification report from an independent surveyor shall be submitted to and approved in writing by the Local Planning Authority. The survey and report shall demonstrate that the surface water drainage system has been constructed in accordance with the details approved pursuant to condition 1. Where necessary, details of corrective works to be carried out along with a timetable for their completion, shall be included for approval in writing by the Local Planning Authority. Any corrective works required shall be carried out in accordance with the approved timetable and subsequently re-surveyed with the findings submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the flood risk is adequately addressed, not increased and users remain safe for the lifetime of the development in accordance with NPPF and Policies of Mid Sussex Council.

Informative:

Erection of flow control structures or any culverting of an ordinary watercourse requires consent from the appropriate authority, which in this instance is West Sussex Lead Local

Flood Authority / and the Local Council (if they have specific land drainage bylaws). It is advised to discuss proposals for any works at an early stage of proposals.

Yours sincerely,

Mat Jackson
Flood Risk Management Team
FRM@westsussex.gov.uk

Annex

The following documents were accessed from the planning portal and considered at the time in review of this application:

- Email Correspondence Wilbury to MSDC February 2026
- Drainage Technical Note prepared by GTA Civils, January 2026