

From: drainage <drainage@midsussex.gov.uk>
Sent: 02 March 2026 13:08:28 UTC+00:00
To: "Catherine Cardin" <Catherine.Cardin@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.03.02 Re: DM/25/3232: Framlingham, 1 The Dell, Haywards Heath, West Sussex RH16 1JG

Dear Catherine,

Thank you for consulting the Flood Risk and Drainage Team on the above application.

We understand the proposed application is for the removal of existing rear conservatory and installation of new single storey rear extension and single storey side extension. (amended description 26.01.2026).

The site lies within Flood Zone 1 very low risk of fluvial flooding.

The Risk of Flooding from Surface Water mapping suggests the site is shown to be at "Very Low" to "High" surface water flood risk (comparable to flood zones 1 to 3b). This is associated with the Stream which runs along the rear boundary of the site.

The proposed extension (built footprint) is located outside of the Flood Zone 3b extent for surface water.

There will be no increase in vulnerability at the site.

The proposed application is a minor development and fits within the EA Standing Advice.

We have no objection to the proposed development on flood risk grounds.

As an advisory, we would suggest the Applicant considers resistance and resilience measures suggested within the EA standing advice and implements any they deem appropriate due to the increased flood risk in the vicinity of this as a residential site (which are classified as 'more vulnerable').

Drainage should be managed via Building Regulations and Building Control, as necessary.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk