

From: Will Langer <will@stephenlanger.co.uk>
Sent: 13 December 2024 10:47:37 UTC+00:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Cc: "daniel.hu@rodgaskin.co.uk" <daniel.hu@rodgaskin.co.uk>; "Planning - Stephen Langer Architects" <planning@stephenlanger.co.uk>
Subject: RE: Applications DM/24/1931 & DM/24/2042 - Burleigh Oaks Stables East Street Turners Hill West Sussex

Hi Anna,

Thank you for this and yes we can agree to the EOT till next Friday.

If there is anything else that you need from me, please don't hesitate to give me a call.

Many thanks

Will

Will Langer MRICS Chartered Surveyor will@stephenlanger.co.uk www.stephenlanger.co.uk Direct Dial: 01892 351070	Stephen Langer Architects combining the art of architecture with the craft of building Stephen Langer Architects York Cottage, Major Yorks Road Tunbridge Wells, Kent TN2 5TP Tel: 01892 524555
---	--

The information contained in this email message and any attachments is intended only for the person or persons to whom it is addressed. Such information is confidential and may be legally privileged and no mistake in transmission is intended to waive or compromise such privilege. If you have received this email in error, please destroy it and notify us on the telephone number printed above. Although we take steps to ensure that our emails and any attachments do not contain viruses, we cannot accept liability for loss if they do, and you should take your own precautionary measures. We and our email software suppliers do not accept liability for loss caused due to corruption, interception or forgery of email. Stephen Langer Associates Ltd. Incorporated in England and Wales Company No: 4561467. Registered Office: York Cottage, Major Yorks Road, Tunbridge Wells, Kent. TN2 5TP

From: Anna Tidey <anna.tidey@midsussex.gov.uk>
Sent: 12 December 2024 16:20
To: Will Langer <will@stephenlanger.co.uk>
Subject: RE: Applications DM/24/1931 & DM/24/2042 - Burleigh Oaks Stables East Street Turners Hill West Sussex

Dear Will

Thank you for your latest email , received Tuesday, the content of which I note. I will not be taking any further advice from ADAS on these applications.

I am writing to advise you that as a result of the publication of the new NPPF, and other workload pressures, I shall be unable to complete my recommendation for the determination of these two applications this week.

I am therefore writing to request your agreement to an Extension of time for the Decision Target Date for both applications to next Friday, 20th December 2024.

Please can you respond by email to me to confirm your agreement to this new Target Date?

I look forward to hearing from you.

Regards

Anna Tidey

Planning Officer

Submit your planning application online.
<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI
Planning Officer
Development Management

Tel: +44 (0)1444 477342
anna.tidey@midsussex.gov.uk <http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.



- SAVE A TREE Only print this email if absolutely necessary.

From: Will Langer <will@stephenlanger.co.uk>
Sent: 10 December 2024 13:02
To: Anna Tidey <anna.tidey@midsussex.gov.uk>
Cc: daniel.hu@rodgaskin.co.uk; Planning - Stephen Langer Architects <planning@stephenlanger.co.uk>
Subject: RE: Planning consultation - DM/24/1931 Burleigh Oaks Stables East Street Turners Hill West Sussex

Hi Anna,

I hope that all is well?

Please find below the response from Ian at West Sussex Fire and Rescue so largely positive now which is good!

Also, please find attached our comments following ADAS's subsequent comments.

Many thanks

Will

Will Langer MRICS Chartered Surveyor will@stephenlanger.co.uk www.stephenlanger.co.uk Direct Dial: 01892 351070	Stephen Langer Architects combining the art of architecture with the craft of building Stephen Langer Architects York Cottage, Major Yorks Road Tunbridge Wells, Kent TN2 5TP Tel: 01892 524555
---	--

The information contained in this email message and any attachments is intended only for the person or persons to whom it is addressed. Such information is confidential and may be legally privileged and no mistake in transmission is intended to waive or compromise such privilege. If you have received this email in error, please destroy it and notify us on the telephone number printed above. Although we take steps to ensure that our emails and any attachments do not contain viruses, we cannot accept liability for loss if they do, and you should take your own precautionary measures. We and our email software suppliers do not accept liability for loss caused due to corruption, interception or forgery of email. Stephen Langer Associates Ltd. Incorporated in England and Wales Company No: 4561467. Registered Office: York Cottage, Major Yorks Road, Tunbridge Wells, Kent. TN2 5TP

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 09 December 2024 09:18
To: Will Langer <will@stephenlanger.co.uk>
Subject: RE: Planning consultation - DM/24/1931 Burleigh Oaks Stables East Street Turners Hill West Sussex

Hi Will,

From the measurements you have provided for the access route, there looks to be sufficient width for suitable access for a fire appliance, with all sections more than 4 metres wide, so access does not look to be a problems and there looks to be an area for turning the fire appliance round to make their exit, so I am satisfied reasonable access to this accommodation has been provided.

With regards to the Plumis - simple sprinkler type system using a pump under a sink, the information provided mentions the system conforms with BS8458 – 2015 requirements and will either fully extinguish or suppress a fire sufficiently to enable the fire service to fully extinguish the fire with the water carried by one fire appliance. The only concern would be if for any reason the fire is not extinguished, there is no supply of water for firefighting in this area, so the fire appliance would then need to leave the site to refill the water tank and then return; if the fire is not fully extinguished there would be the risk of re-ignition while the fire appliance is away from the site.

Regards

Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his 

[Click here to find out why we use pronouns in our signatures](#)



From: Will Langer <will@stephenlanger.co.uk>

Sent: Friday, December 6, 2024 8:44 AM

To: FRS Water and Access <frs.waterandaccess@westsussex.gov.uk>

Cc: Anna Tidey <anna.tidey@midsussex.gov.uk>; Planning - Stephen Langer Architects
<planning@stephenlanger.co.uk>

Subject: Planning consultation - DM/24/1931 Burleigh Oaks Stables East Street Turners Hill West Sussex

****EXTERNAL****

Hi Ian,

Thank you for taking the time to speak to me the other week about the fire access at Burleigh Oaks Stables.

Further to our conversation, please find attached a map (2 pages) showing the access to the site and the minimum widths of the lane. Let me know if you have any thoughts.

We were also hoping to install a system like the one found at <https://plumis.co.uk/taphead> This is a simple sprinkler type system using a pump under a sink etc.

Many thanks in advance

Will

Will Langer MRICS Chartered Surveyor will@stephenlanger.co.uk www.stephenlanger.co.uk Direct Dial: 01892 351070	Stephen Langer Architects combining the art of architecture with the craft of building Stephen Langer Architects York Cottage, Major Yorks Road Tunbridge Wells, Kent TN2 5TP Tel: 01892 524555
---	--

The information contained in this email message and any attachments is intended only for the person or persons to whom it is addressed. Such information is confidential and may be legally privileged and no mistake in transmission is intended to waive or compromise such privilege. If you have received this email in error, please destroy it and notify us on the telephone number printed above. Although we take steps to ensure that our emails and any attachments do not contain viruses, we cannot accept liability for loss if they do, and you should take your own precautionary measures. We and our email software suppliers do not accept liability for loss caused due to corruption, interception or forgery of email. Stephen Langer Associates Ltd. Incorporated in England and Wales Company No: 4561467. Registered Office: York Cottage, Major Yorks Road, Tunbridge Wells, Kent. TN2 5TP

CAUTION: This email originated from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe.

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is

legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.