

**MID SUSSEX
DISTRICT COUNCIL**

Oaklands Road, Haywards Heath, West Sussex RH16 1SS

Switchboard: 01444 458166
DX 300320 Haywards Heath 1

Fax: 01444 477464
www.midsussex.gov.uk

Date: 17 September 2026

Stefan Galyas
Mid Sussex District Council
Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Dear Stefan,

RE: **DM/26/2018 - Graftons Brighton Road Warninglid Haywards Heath West Sussex RH17 5SU.**

Thank you for your consultation on the above site. We have reviewed the application and information relating to drainage and flood risk and wish to make the following comments.

The applicant is applying for the outline application for the erection of one Self-build dwelling with all matters reserved except access.

Following a review of the submitted information, we have no objection on surface water grounds. Due to the site, size, location, and type of development **we would recommend the approval of the application** with the following conditions:

Condition 1: At reserved matters stage, a detailed surface water drainage scheme for the site should be submitted to and approved in writing by the Local Planning Authority. The surface water drainage scheme must prioritise the use of source control Sustainable Drainage Systems (SuDS) in consideration of the National Standards for SuDS and demonstrate no increase in flood risk as a result of the Proposed Development with sufficient supporting evidence provided to support its viability including supporting calculations for the 100% AEP (1 in 1 year), 3.33% AEP (1 in 30 year), 3.33% AEP (1 in 30 year) plus climate change, the 1% AEP (1 in 100 year) and the 1% AEP (1 in 100) plus climate change critical storms. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring and winter infiltration testing to BRE DG365, or similar approved, will be required to support the design of any infiltration drainage. The scheme shall subsequently be implemented in accordance with the approved details before the development is completed.


Reason: *To ensure the flood risk is adequately addressed and not increased in accordance with NPPF and Policies of Mid Sussex District Council.*

Condition 2: The development hereby approved shall not be occupied until details of the maintenance and management of the sustainable drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The drainage scheme shall be implemented prior to the first occupation of the development hereby approved and thereafter managed and maintained in accordance with the approved details in perpetuity. The Local Planning Authority shall be granted access to inspect the sustainable drainage scheme for the lifetime of the development. The details of the scheme to be submitted for approval shall include:

- I. a timetable for its implementation.



Awarded for excellence



**MID SUSSEX
DISTRICT COUNCIL**

Oaklands Road, Haywards Heath, West Sussex RH16 1SS

Switchboard: 01444 458166
DX 300320 Haywards Heath 1

Fax: 01444 477464
www.midsussex.gov.uk

- II. details of SuDS feature and connecting drainage structures and maintenance requirement for each aspect including a drawing showing where they are located.
- III. a management and maintenance plan for the lifetime of the development which shall include details of design life and the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime. This will include the name and contact details of any appointed management company.

Reason: *To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Policies of Mid Sussex District Council.*

Yours sincerely,

Flood Risk and Drainage Team

Mid Sussex District Council



Awarded for excellence