

From: Scott@EllisdonArchitecturalAssociates.co.uk
<scott@ellisdonarchitecturalassociates.co.uk>
Sent: 08 September 2026 14:00:33 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Cc: "Jane Cooper" <Jane.Cooper@midsussex.gov.uk>
Subject: Re: EHO comments from Jane Cooper re: DM/26/1940 - 40 Mill Green Road,
Haywards Heath

Thanks Anna & Jane.

I will revert back.....

Many Thanks,

Scott Ellisdon
BA (hons) Architecture
HNC Technical Construction & Management

M: 07828 189525

W: www.EllisdonArchitecturalAssociates.co.uk

E: Scott@EllisdonArchitecturalAssociates.co.uk

COMPANY NUMBER: 13380160

Double O Architectural Management LTD

(Trading as Ellisdon Architectural Associates)



On Tue, Sep 8, 2026 at 12:45 PM Anna Tidey <anna.tidey@midsussex.gov.uk> wrote:

Good afternoon Scott

I have received comments this morning from Jane Cooper (MSDC Environmental Health Officer) regarding the A/C unit which has been added to this application, see her email in full below.

Jane has recommended:

- If this is the preferred/or only location, please can the application be supported by a BS 4142 assessment, which I will then send on to Jane for her further advice.
- Or alternatively your clients might consider relocating the unit,
- Or review the choice of the unit (to substitute it with a quieter unit)
- Or to provide some form of enclosure or screening to mitigate the noise impact.

I have yet to visit the site, but I shall be arranging that with you in the following week or so.

In the meantime please can you talk to your clients regarding the above suggestions and let me know how they wish to proceed, if there will be further submissions/revisions or whether they want to remove the A/C unit from the proposal?

Thank you. I await your comments.

Regards

Anna

Submit your planning application online.

<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI

Planning Officer

Development Management

Tel: [+44 \(0\)1444 477342](tel:+44%201444%20477342)

anna.tidey@midsussex.gov.uk

<http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.

 - **SAVE A TREE** Only print this email if absolutely necessary.

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>

Sent: 08 September 2026 11:48

To: Anna Tidey <anna.tidey@midsussex.gov.uk>

Subject: DM/26/1940

Hi Anna,

I have several concerns regarding this application.

1. The consultant has only considered the impact of noise from the ac unit on the adjoining neighbour at number 39 and not the residents at 41A and 41B. I have checked the calculation carried out by Scott Ellisdon and believe that he has underestimated the predicted noise level from the ac unit at the nearest residential dwelling (39). This is because the proposed unit will be positioned in a corner, and therefore there are three reflective surfaces to consider, but Scott has only factored in one. I do however accept that this resident will largely be shielded from noise by the structure of the building at number 40.
2. Without further details, it is difficult to predict the impact of noise on residents at 41A and 41B with certainty, but a basic calculation indicates that it is likely to have an impact on amenity.
3. Although the applicants have indicated that the ac unit will be used between 07.00 and 23.00, this would be difficult to regulate through the planning regime. If the unit were to be used at night, and a complaint subsequently received by the Environmental Protection team, we would be duty bound to investigate and take any necessary enforcement. It would therefore seem prudent to ensure that the unit is suitable for use at night to avoid possible issues in the future.

If the applicant would like to proceed with the ac unit in its current proposed location, can they please provide a BS 4142 assessment to accurately predict how noise from the unit will affect neighbours. Alternatively, they may wish to consider relocating the unit, installing a quieter unit or providing some form of enclosure or screening.

Please will you put these points to the applicant.

Thanks,

Jane Cooper

Environmental Health Officer

Environmental Health

Tel: [+44 \(0\)1444 477437](tel:+44(0)1444477437)

Email: jane.cooper@midsussex.gov.uk

Website: www.midsussex.gov.uk



“Working together for a better Mid Sussex”

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling [+44 \(0\) 1444 458 166](tel:+44(0)1444458166) and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be

responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.