

Katherine Williams

From: Katherine Williams
Sent: 03 April 2025 14:16
To: Tim Corless
Subject: RE: DM/25/0635 1 Eastern Cottages, Lewes Rd, Lindfield

Dear Tim,

Thank you for the amended plans.

Following the additional information Emily raises no objection and the conditions can be discharge.

The decision notice will be issued shortly this afternoon.

Kind Regards

Katherine Williams BSc (Hons) MSc
Senior Planning Officer
Development Management
Mid Sussex District Council
01444 477214
www.midsussex.gov.uk



Working together for a better Mid Sussex



Sent: 03 April 2025 10:42

To: Katherine Williams <Katherine.Williams@midsussex.gov.uk>; Emily Wade <emily.wade@midsussex.gov.uk>

Subject: Re: DM/25/0635 1 Eastern Cottages, Lewes Rd, Lindfield

Morning Katherine,

Thanks a lot for the quick feedback, it's really appreciated once again.

Attached is, hopefully, the final design - which addresses the timber frame for the side door, which is now drawn as painted timber and also the sash window, also which now will be painted timber.

In relation to the felt covering the extension, I can confirm this will be dark grey yes.

Thanks,
Tim

On 2 Apr 2025, at 17:10, Katherine Williams <Katherine.Williams@midsussex.gov.uk> wrote:

Dear Tim,

Thank you for your email.

Please see the attached further comments from Emily on the further information, which requires further information and clarification.

Kind Regards

Katherine Williams BSc (Hons) MSc
Senior Planning Officer
Development Management
Mid Sussex District Council
01444 477214
www.midsussex.gov.uk
<image001.png>
Working together for a better Mid Sussex



- **SAVE A TREE** Only print this email if absolutely necessary.

Sent: 02 April 2025 14:54

To: Katherine Williams <Katherine.Williams@midsussex.gov.uk>; Emily Wade <emily.wade@midsussex.gov.uk>

Subject: Re: DM/25/0635 1 Eastern Cottages, Lewes Rd, Lindfield

Hi Katherine,

Apologies for following up so soon, but is there anything else we would need in order to remove the conditions so we can start the building work or is everything in order for approval?

Our builder is still waiting on us to be able to move forward with the project, in the coming week or so.

If we could get this over the line as soon as possible, that would be hugely hugely appreciated.

Thank you very much,
Tim

Hi both,

Hope you had great weekends.

Just to complete on the below, our builder believes the following brick will be best matched to the house. He is an ex bricklayer and also surveyed a fair few of his trade contacts who agree.

https://build4less.co.uk/products/flb-selected-dark-facing-brick-65mm-x-215mm-x-102mm?srsId=AfmBOoocTg2lDI_Y0HjaBV8ZORSPeT9xnFaOs5z-n95tj9_GGvZ1HFs20co

The roof will be felt with coping stone, which I believe matches next door.

Is that enough detail for conditions to be approved, along with the updated drawings.

Thanks a lot,
Tim

On 28 Mar 2025, at 14:48, Tim Corless

Good afternoon both,

Thank you for your comments Emily, I've given a brief summary below in response and also attached updated drawings for you.

I've also added in the brochure for the door / window company we will be using, if this hasn't been seen already. <https://cwgchoices.com/>

In terms of the brick and roof details, we are speaking with the builder today to get more on this for you - he has mentioned it is quite hard to provide details for the brick without starting work but he is going to evaluate this request.

There may have been a slight misunderstanding in the sign off of our planning permission, as we asked the question if the side door to the house (which can't be seen from the road) could be uPVC, to which there were no objections. We have amended this in the attached drawings to be painted timber, in line with your comments if that is required.

In terms of the rear of the house in the new extension there will be no uPVC, this will be white aluminium for the bi-fold door and window also - which will match in terms of style to the house, if the window needs to be timber again we can do this.

The drainpipes will definitely be painted metal, this was an error from the architect - which has been corrected.

Again I just want to make sure it's clear, the we are doing everything we can to maintain the character of the original house and area - which is at the forefront of the project. Knocking down quite an ugly uPVC conservatory and turning this into a more

fitting structure, we hope will give back more to the house than has previously been added.

Thanks,
Tim

<B267483_PR-DoC_Details_v02.pdf>

On 27 Mar 2025, at 16:51, Katherine Williams
<Katherine.Williams@midsussex.gov.uk> wrote:

Dear Tim,

As per Emily's email this afternoon, please see her below comments and request for further information.

Kind Regards

Katherine Williams BSc (Hons) MSc
Senior Planning Officer
Development Management
Mid Sussex District Council
01444 477214
www.midsussex.gov.uk

<image002.png>

Working together for a better Mid Sussex

 - **SAVE A TREE** Only print this email if absolutely necessary.

From: Emily Wade
<Emily.Wade@midsussex.gov.uk>
Sent: 27 March 2025 14:58
To: Katherine Williams
<Katherine.Williams@midsussex.gov.uk>
Subject: DM/25/0635 1 Eastern Cottages, Lewes Rd, Lindfield

Hi Katherine

Comments on the above discharge of conditions application.

Condition 3: Materials

We do not appear to have any detail of facing or roofing materials to the extension, beyond a photograph of some brickwork to show colour. We would need a full specification for both, including manufacturer, range and/or product name, and colour, as applicable.

Condition 4: Detailed drawings

We have one page of sectional drawings which appear acceptable in respect of the eaves detail and depth of reveal, however for windows and external doors we would expect to see large scale elevational as well as sectional drawings, and these should also be marked to show materials and finishes as per the requirements of the condition. I am concerned to see that one of the detailed sections is titled 'Standard uPVC outer frame'. We would not accept uPVC as a framing material to windows (or doors) to a period building (or an extension to one) within an conservation area. To the extension we would expect to see a timber framed sash window and timber or possibly metal framed bifold doors, in an appropriate finish. Details of the new side entrance door to the existing house must also be provided- we would expect this to be of painted timber in an appropriate design.

I also note that the submitted sectional drawing shows uPVC downpipes, which will not be acceptable. Rainwater goods should be of painted metal as per the requirements of condition 5 of the permission.

Thanks,

Emily

Please note that this advice is given at Officer level only and is without prejudice to the formal decision of the District Council.

Submit your planning application online.

<http://www.planningportal.gov.uk>

Emily Wade Ma MSc

Conservation Officer

Planning Services

Tel: +44 (0)1444 477385

emily.wade@midsussex.gov.uk <http://www.midsussex.gov.uk>

<image001.jpg>

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject

matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

<mime-attachment>