

Hi Nick

Please find attached a marked up copy of drawing WN0023692-1 1 o 1 confirming 8 FHs are required in total and they all need to be on a minimum 90mm sized main.

The installation(s) needs to conform to the Standard Specification BS750 and relevant revisions, including FH cover(s).

The developer is to pay for the cost of the installation(s) and WSFSR will maintain it/them once inspected and adopted on to our mapping.**

Please arrange for this office to be informed as soon as the installation(s) are in place and ready for our inspection, which ideally should be before the properties are occupied. ****This is important as WSFRS is unable to adopt any FHs or add the locations to our mapping (which the fire fighters see) until this inspection has taken place and the site will remain at risk if there is any delay in us being informed.**

If you have any questions or updates for WSFRS regarding this mains construction then please contact us via email frs.waterandaccess@westsussex.gov.uk and quote our ref C04078.

Please acknowledge receipt of this email and confirm you will abide by our request to notify this office as soon as the FHs are in place, fully accessible and ready for us to inspect/adopt.

Lastly, I have just noticed you have the incorrect address on the letter to Ian Stocks the full correct details are: Ian Stocks, Water and Access Manager, Water and Access Department (Protection), Bognor Fire Station, West Meads Drive, Bognor PO21 5TB although continue to send in via email to frs.waterandaccess@westsussex.gov.uk

Thank you



Julie McCarthy
Support Officer, Water and Access

Phone: 0330 222 3117

frs.waterandaccess@westsussex.gov.uk – use for all FH queries

Julie.mccarthy@westsussex.gov.uk

Postal address:
Water and Access, Protection
Bognor Fire Station, West Meads Drive
Bognor, PO21 5TB

My pronouns are she/her/hers 🏳️‍🌈