

From: planninginfo@midsussex.gov.uk <planninginfo@midsussex.gov.uk>
Sent: 28 April 2026 12:25:07 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Mid Sussex DC - Online Register - Consultee Comments for Planning Application
DM/26/0596

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 28/04/2026 12:25 PM from Adam Dracott on behalf of Environmental Protection.

Application Summary

Reference:	DM/26/0596
Address:	The Royal British Legion Woodland Road Hassocks West Sussex BN6 8HE
Proposal:	Change of use of the existing vacant social club (use Class F2) to six residential units (use Class C3), with a first floor extension proposed above the existing ground floor addition to the front of the building, together with the installation of new windows, roof lights, solar panels and heat pumps and a bin and cycle store (Amended plans showing ASHPs and material details received 24.04.26)
Case Officer:	Stefan Galyas

[Click for further information](#)

Comments Details

Comments:	The amended plans show the ASHPs on the northern elevation of the building. However, the acoustic assessment has been made on the basis that the ASHPs are positioned on the east elevation. The noise impact from the ASHPs on the properties to the north of the development site has not therefore been adequately assessed. Whether a significant adverse impact as a result of noise, has not been addressed. A revision to the noise assessment should be provided to enable proper consideration of this proposal.
-----------	---

Kind regards

