

From: Ian Stocks <ian.stocks@westsussex.gov.uk>
Sent: 21 September 2026 11:01:27 UTC+01:00
To: "planningsystemssupport" <planningsystemssupport@midsussex.gov.uk>
Subject: Planning consultation - DM/26/1963 - Land Between Edwin Street And Hammonds Ridge Burgess Hill West Sussex

You don't often get email from ian.stocks@westsussex.gov.uk. [Learn why this is important](#)
FAO: Stefan Galyas

Daer Stefan,

Having viewed the details for planning application no. DM/26/1963 for the Construction of 9 No. residential dwellings, including associated parking and landscaping. Amended plans and supporting details received 24/09/2026, the fire Service access and the supply of water meets with the requirements of Approved Document B (AD-B) Volume 1: B5 requirements, with suitable access for a fire appliance, a turning facility and a supply of water within the required distance and therefor considered satisfactory by West Sussex Fire & Rescue Service

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, Wes

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
