

From: Phil Herbert <hhrfccommercial@aol.com>
Sent: 28 March 2025 15:08:08 UTC+00:00
To: "Steven King" <steven.king@midsussex.gov.uk>
Subject: HHRFC Clubhouse Whitemans Green Cuckfield West Sussex RH17 5HX - DM/25/0124
Attachments: 7507-HJCE-00-XX-CA-D-3003-P02-SURFACE WATER HYDRAULIC CALCULATIONS.pdf, 7507-HJCE-00-XX-DR-D-3000-C04-DRAINAGE LAYOUT.pdf, 7507-HJCE-00-XX-CA-C-4500-P01-INFILTRATION CALCULATIONS.pdf, 7507 - Drainage Maintenance Schedule.pdf

Hi Steve,

Please see below comments and attachments showing calculations from our drainage engineer.

Kind Regards

Phil Herbert

Commercial Director
Haywards Heath Rugby Football Club Limited
07508 521649

Please see attached updated calcs to suit the request for a surcharged outfall.

As discussed, the information around the drainage design that you submitted for the previous application should be suitable to discharge the comments made.

The only point to be made is that the previous calcs that allowed for the padel court had a CV value of 0.75 and 0.84 for summer and winter rainfall (approval of the previous calcs are attached). The existing system has not been designed for a CV value of 1 as requested in the recent correspondence.

Kind regards

Dave Moffatt



Tel: 01924 824433

DD: 01924 570131

Email: dmoffatt@hjce.co.uk

Web: www.hjce.co.uk



Correspondence address:

Connaught House, Park View, Lofthouse, WF3 3HA

Registered office:

13 Huddersfield Road, Barnsley, S70 2LW

Company Registration number: 06689016 (England & Wales) VAT Registration number: 941 7222 35