

From: drainage <drainage@midsussex.gov.uk>
Sent: 12 January 2026 18:24:05 UTC+00:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.01.12 Re: Further information submission DM/25/0240 - Woodside
Grange Woodsland Road Hassocks West Sussex BN6 8EX

Dear Anna,

The Flood Risk and Drainage Team have reviewed the updated report and have the following comments:

It is unclear how the surface and foul water pipework to the north of the proposed dwelling would be feasible with the information that has currently been provided. For instance, the foul invert level is above the adjacent surface water manhole cover level. Further information is required.

A timetable of implementation should be supplied.

Following receipt of the additional information requested, we shall review and provide further comments on this application.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk