

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 27 May 2026 15:22:55 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Hydrant condition - DM/25/3059 Badgers Brook London Road Bolney Haywards Heath West Sussex RH17 5PY
Attachments: HC - DM.25.3059 Badgers Brook London Road Bolney Haywards Heath West Sussex RH17 5PY.docx

FAO: Andrew Watt,

Dear Andrew,

Please find attached a planning condition for application no. DM/25/3059 for the requirement of an additional fire hydrant. Currently the nearest Hydrant to these proposed properties is 200 metres away. The supply of water for firefighting for a domestic premises should be within 175 metres.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection


West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frswaterandaccess@westsussex.gov.uk

Bognor Regis Fire Station, West Meads Drive, West Sussex, PO21 5TB



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
