

From: Jo Dawes <Jo@planitconsulting.co.uk>
Sent: 29 September 2025 13:49:23 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Subject: RE: Drainage response for DM/24/2263 - Lake House Old Hollow Copthorne
Crawley West Sussex RH10 4TB

Dear Anna,

Thank you for your email.

I am delighted to see that we are finally moving towards a favourable decision. I look forward to receiving a set of pre-commencement conditions shortly. We agree to an EOT until 6th October and would hope that you will do everything in your powers to ensure that this deadline can be met given the significant delays.

Best regards

Jo Dawes

Senior Planner

Planit Consulting

Phone: 01483 415753

Email: jo@planitconsulting.co.uk

Website: www.planitconsulting.co.uk

Address: 3 Innovation Place, Douglas Drive, Godalming, Surrey GU7 1JX



My working hours: Monday to Wednesday 08.30 – 15.00



Save money, energy and the environment – do you need to print this email?

This is an email from Planit Consulting. The content of this email is confidential to the ordinary user of the email address to which it was sent. If you have received this email in error, please accept our apologies. We should be obliged if you would inform us by telephone on +44 (0)1483 415753 or email us at jo@planitconsulting.co.uk

Our website www.planitconsulting.co.uk gives information about our Privacy Policy and how we process your personal data, including your consent.

Cybercrime and fraud is on the increase. If you receive an email or other electronic communication purporting to be from this firm but contact us immediately at the telephone number or email address on our website.

From: Anna Tidey <anna.tidey@midsussex.gov.uk>

Sent: 29 September 2025 13:17

To: Planit Planning Applications <applications@planitconsulting.co.uk>; Janet Long <janet@planitconsulting.co.uk>; Jo Dawes <Jo@planitconsulting.co.uk>

Cc: Joanne Fisher <Joanne.Fisher@midsussex.gov.uk>

Subject: Re: Drainage response for DM/24/2263 - Lake House Old Hollow Copthorne Crawley West Sussex RH10 4TB

Dear Janet and Jo

I am sorry for my delay in corresponding with you on this application. Both you and your client will be pleased to know that I received the awaited Drainage consultee comments on Friday afternoon last week, see below, so I can now resume writing my recommendation report. I shall draft a set of planning conditions to include the recommended Drainage condition (see below) and aim to send these on to you later this week for your perusal.

I aim to complete my recommendation report this week, but for your information I am away from the office tomorrow.

Please can I request an Extension of time agreement to 6th October 2025 to allow for the Senior Officer review and sign off procedure?

A return email to confirm this EOT will be acceptable.

Thank you.

Regards
Anna

Submit your planning application online.
<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI
Planning Officer
Development Management

Tel: +44 (0)1444 477342
anna.tidey@midsussex.gov.uk <http://www.midsussex.gov.uk>

Working together for a Better Mid Sussex.



- SAVE A TREE Only print this email if absolutely necessary.

From: Emma Jackson <Emma.Jackson@midsussex.gov.uk>
Sent: 26 September 2025 14:09
To: Anna Tidey <anna.tidey@midsussex.gov.uk>
Cc: drainage <drainage@midsussex.gov.uk>; Joanne Fisher <Joanne.Fisher@midsussex.gov.uk>
Subject: 2025.09.26 Re: DM/24/2263 - Lake House Old Hollow Copthorne Crawley West Sussex RH10 4TB

Dear Anna,

Thank you for reconsulting the Flood Risk and Drainage Team on the above application. We have reviewed the TN01 – Discussion of LLFA Consultation Response to DM/24/2263 by Motion 19 February 2025 which responds to MSDC's earlier comments dated 12/12/24 and have the following comments.

Flood Risk

As the proposed development is for a replacement dwelling with annexe accommodation the applicant has demonstrated that the proposed development fits within the EA Standing Advice for more vulnerable developments. There is no increase in the number of residential units, vulnerability at the site or displacement of flood water. The applicant has demonstrated safe escape can be provided.

We have no objection on Flood Risk grounds. This is subject to:

- The development is built as per the submitted plans

- Proposed Ground Floor Plan- Wider Area DRAWING NUMBER:A.102
DATE:31/03/2025
- Proposed Ground Floor Plan- DRAWING NUMBER:A.103 DATE:31/03/2025
- Proposed First Floor Plan - DRAWING NUMBER:A.104 DATE:31/03/2025
- No sleeping accommodation on the ground floor
- The proposed finished floor levels (FFLs) will be set no lower than 82.5mAOD, with all sleeping accommodation to be set at a minimum of 83.4 mAOD.

As an advisory, we would suggest the Applicant considers the resistance and resilience measures suggested within the EA advice and implements any they deem appropriate due to the increased flood risk in the vicinity of this as a residential site (which are classified as 'more vulnerable').

Surface Water Drainage

It is proposed that the development will discharge into the adjacent watercourse at an attenuated rate via a geocellular tank. The applicant should locate all attenuation structures and flow controls within the application boundary.

The principle of the surface water drainage system is considered acceptable. Calculations will need to be provided to demonstrate betterment onsite at the detailed design stage. Cross sections of the gravel path should also be provided to demonstrate that it will provide the same pollution mitigation as permeable paving.

Information into our general requirements for detailed surface water drainage design is included within our 'General Drainage Information Guide'. This level of information will be required to address the recommended drainage condition.

To ensure the final drainage design meets with the latest design requirements we would advise the applicant to confirm the design parameters required in relation to climate change etc prior to undertaking detailed design.

Foul Water Drainage

It is proposed that the development will discharge foul water through an existing treatment plant if still compliant with current regulations. This will then discharge into the adjacent lake.

Details of any new sewage treatment plant should be provided at the detailed design stage. The principle of the foul water drainage system is considered acceptable

Information into our general requirements for detailed foul water drainage design is included within our 'General Drainage Information Guide'. This level of information will be required to address the recommended drainage condition.

To ensure the final drainage design meets with the latest design requirements we would advise the applicant to confirm the design parameters required prior to undertaking detailed design.

We recommend the following condition is utilised on this application:

Condition Recommendations

C18F - Multiple dwellings/units

The development hereby permitted shall not commence unless and until details of the proposed foul and surface water drainage and means of disposal have been submitted to and approved in writing by the local planning authority. No building shall be occupied until all the approved drainage works have been carried out in accordance with the approved details. The details shall include a timetable for its implementation and a management and maintenance plan for the lifetime of the development which shall include arrangements for adoption by any public authority or statutory undertaker and any other arrangements to secure the operation of the scheme throughout its lifetime. Maintenance and management during the lifetime of the development should be in accordance with the approved details.

Reason: To ensure that the proposal is satisfactorily drained and to accord with Policy DP41 of the Mid Sussex District Plan 2014 - 2031 and Policy ...'z'... of the Neighbourhood Plan.

Ordinary Watercourse Consent

The applicant is advised that if any new development (including construction activities) is to take place within 5 metres of any drain or watercourse. It is important that Ordinary Watercourse Consent (OWC) is fully obtained before works are undertaken near this watercourse. It is important to understand that this Planning consultation deals with the flood risk impact of the proposed development, but the OWC will deal with the impact of the watercourse alteration. So, whilst the OWC is not a Planning matter, it will need to run alongside this application. Details for OWC are in the advice sections of this consultation. OWC application: <https://www.westsussex.gov.uk/fire-emergencies-and-crime/dealing-with-extremeweather/dealing-withflooding/flood-risk-management/ordinary-watercourse-land-drainage-consent/>

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software

viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.