

From: Graham Middle <graham.middle@lm-associates.co.uk>
Sent: 04 September 2026 16:01:48 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Subject: RE: Latest Drainage comments and EOT request for DM/25/2155 - Nupur Indian Restaurant 122 High Street Hurstpierpoint Hassocks West Sussex BN6 9PX
Attachments: 1725.P02A Nupur-Model.pdf, Inspection & Maintenance Plan.pdf

Good morning Anna

Thank you for your telephone call and subsequent e-mail yesterday afternoon.

I can confirm agreement to the proposed EOT on behalf of our client.

With regards to the Council's external drainage consultants comments as provided with your e-mail I can advise a revised drainage drawing is attached, together with a ??????.

However I would suggest the external consultant is being over-zealous in objecting to the submitted proposals and the issues raised could be dealt with by an imposed drainage condition to be discharged prior to the dwelling being commenced on site.

Regards

Graham Middle

Principal

BA (Hons). Dip Arch. RIBA. CIOB. CIH.

L.M. Associates Ltd

Tel: 01444 484711

www.lm-associates.co.uk



From: Anna Tidey [mailto:anna.tidey@midsussex.gov.uk]
Sent: 03 September 2026 16:27
To: graham.middle
Subject: Latest Drainage comments and EOT request for DM/25/2155 - Nupur Indian Restaurant 122 High Street Hurstpierpoint Hassocks West Sussex BN6 9PX

Dear Graham

Further to my call please see the latest Drainage comments for the above application, which you may wish to address.

As I explained I shall be grateful if you can confirm your agreement to a further EOT to 11.09.2026 to allow consideration of the application in light of the new NPPF policies.

I look forward to hearing from you.

Regards

Anna

Submit your planning application online.

<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI
Planning Officer
Development Management

Tel: +44 (0)1444 477342

anna.tidey@midsussex.gov.uk

<http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.



- **SAVE A TREE** Only print this email if absolutely necessary.

From: drainage <drainage@midsussex.gov.uk>

Sent: 05 August 2026 12:51

To: Anna Tidey <anna.tidey@midsussex.gov.uk>

Cc: drainage <drainage@midsussex.gov.uk>

Subject: 2026.08.05 - DM/25/2155 - Nupur Indian Restaurant 122 High Street Hurstpierpoint Hassocks West Sussex BN6 9PX

Dear Anna,

Thank you for reconsulting the Flood Risk and Drainage Team on the above application.

We have reviewed the Drainage Layout Drawing 1725.P02 received on 24.07.2026 together with the Flood Risk and Drainage Response Statement and have the following concerns.

The submitted drainage layout shows the proposed attenuation feature located entirely beneath the proposed dwelling.

The submitted Maintenance and Management Plan states that the attenuation tank/storage will be subject to an "annual inspection via access cover". However, no access cover is shown on the submitted drawings and, given the proposed location of the attenuation feature beneath the dwelling, it has not been demonstrated how the system can be safely inspected, maintained, repaired or replaced, if required, throughout the lifetime of the development.

Furthermore, no system-specific maintenance information has been provided to demonstrate how routine inspection or other maintenance activities would be undertaken once the dwelling has been constructed. Consequently, the applicant has not demonstrated that the proposed surface water drainage system can be effectively maintained and remain functional for the lifetime of the development.

In the absence of this information, the Flood Risk and Drainage Team cannot be satisfied that the proposed surface water drainage strategy will continue to operate as intended without increasing flood risk on or off the site.

The Flood Risk and Drainage Team therefore **objects** to the proposed development as the applicant has failed to demonstrate that the proposed surface water drainage system can be adequately maintained for the lifetime of the development, contrary to Policy DP41 of the Mid Sussex District Plan 2014–2031.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.



Virus-free. www.avast.com