

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 14 August 2025 15:43:09 UTC+01:00
To: "Susan Dubberley" <Susan.Dubberley@midsussex.gov.uk>
Subject: DM/24/3077

Hi Sue,

Adam's comments regarding this application made 24/12/24, address the issue of noise from the mechanical services and refrigeration plant. The report by Sharps Redmore dated December 24 acknowledges that the plant for this development has not yet been finalised, which is why Adam recommended the following condition:

Prior to the commencement of the development hereby permitted, a scheme for protecting the nearest residential properties from noise from mechanical services and refrigeration plant that takes account of the conclusions in the noise assessment by Sharps Redmore dated December 2024 (Project no. 2422720), shall be submitted and approved in writing by the Local Planning Authority. All works, which form part of the approved scheme shall be maintained in accordance with the approved details

Happy to discuss if necessary.

Kind regards,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk



"Working together for a better Mid Sussex"